
**User's
Manual**

**Models 2533E32, 2533E33
2533E42 and 2533E43
Digital Power Meter
(Three-Phase AC and DC/AC)**

IM 2533E-03E

CONTENTS

<i>Section</i>	<i>Title</i>	<i>Page</i>
	HOW TO USE INSTRUCTION MANUAL	0-3
	WHEN THE INSTRUMENT HAS ARRIVED	0-4
1. OUTLINE OF PRODUCT		1-1
1-1.	General	1-1
1-2.	Features	1-1
1-3.	Designations and Functions	1-2
1-4.	Specifications	1-6
1-5.	Operating Principle	1-9
1-6.	External Dimensions	1-10
2. HANDLING		2-1
2-1.	General Operating Procedure	2-1
2-2.	Installing and Replacing Battery	2-2
2-3.	Installation	2-5
2-4.	Wiring Procedure	2-7
2-4-1.	Power Measurement of Single-Phase Two-Wire (1 ϕ 2W) System	2-8
2-4-2.	Power Measurement of Three-Phase Three-Wire (3 ϕ 3W) System	2-10
2-4-3.	Power Measurement of Single-Phase Three-Wire (1 ϕ 3W) System	2-12
2-4-4.	Power Measurement of Three-Phase Four-Wire (3 ϕ 4W) System	2-13
2-4-5.	Power Measurement of Three-Phase Three-Wire (3 ϕ 3W) System	2-14
2-4-6.	Correction for Self-Consumed Power	2-15
2-5.	Turning on Power	2-17
2-6.	Setting Voltage and Current Ranges (RANGE)	2-19
2-7.	Digital Display (DISPLAY)	2-20
2-8.	Selecting Digital Display (DISPLAY)	2-22
2-9.	Selecting Measurement Mode (MODE)	2-26
2-10.	Setting Scaling (SCALING) Factor	2-28
2-11.	How to Use Connector	2-30
2-12.	Setting Internal Switches	2-33
3. MAINTENANCE		3-1
3-1.	Storage	3-1
3-2.	Replacing Fuse	3-1
4. REFERENCES		4-1
4-1.	Error Code and Hardware Configuration Lists	4-1
5. SCHEMATIC DIAGRAMS AND ELECTRONIC PARTS LIST		5-1
SUPPLEMENT		
•	Model 2533E Digital Power Meter Service Manual	IM 2533E-03Es
•	Customer Maintenance Parts List	CMPL2533-01E

NOTES

- To ensure safety, turn off power of the measured device before connecting an input signal.
- Models 2533E32 and 2533E33 are intended for AC signal only. Do not apply DC or DC-superposed signal. Otherwise, the DC component would be ignored in measurement and an excessive DC input might adversely affect the instrument itself. Full wave or half wave rectification which has asymmetrical waves on positive and negative sides would superpose a DC component.
- Models 2533E42 and 2533E43 can measure AC–DC dual signals.
Either DC or AC signal can also be measured. When AC signals superimposed on DC signals are measured, sum of AC and DC signals is measured (AC and DC components cannot be measured or displayed independently).
- Reactive power (var), apparent power (VA) and power factor (PF) of the instrument are obtained by digital computation from voltage, current, effective power, etc.
When distorted waveshapes are measured, differential in measured values using this instrument and other instrument with different principle of measurement may occur.

HOW TO USE INSTRUCTION MANUAL

This instruction manual describes the functions, specifications and operations of the three-phase digital power meters 2533E32, 2533E33, 2533E42 and 2533E43.

For GP-IB Interface, RS-232-C Interface, Frequency Measurement option: /FRQ and Integrator Function: /INTEG, refer to a separate manual.

Instrument Name	Instruction Manual No.
Digital Power Meter (Single-phase, AC, DC/AC)	IM 2533E-01E
Digital Power Meter (Three-phase Three-wire, AC, DC/AC)	IM 2533E-03E
Digital Power Meter (Three-phase Four-wire, AC, DC/AC)	
Frequency Measurement	
Integrator Function	IM 2533E-50E
GB-IB Interface	IM 2533E-51E
RS-232-C Interface	IM 2533E-70E

The manual consists of five chapters given below.

Chapter 1. OUTLINE OF PRODUCT

This chapter describes the outline, features, functions and specifications of the Model 2533E. Read it through before use to get an overview of the functions of the instrument.

Chapter 2. HANDLING

The wiring procedure and operation methods are explained here. By reading the manual and operating the instrument together, increases the speed of learning and shows proper handling and operation.

Chapter 3. MAINTENANCE

Chapter 4. REFERENCES

"Error codes" and other useful information are explained.

Chapter 5. SCHEMATIC DIAGRAMS AND ELECTRONIC PARTS LIST

Conventions Used in This Manuals

Symbols Used

The following symbols are used in this manual.

WARNING

... Describes precautions to be observed to prevent danger of injury or death to the user due to electrical shock that may be incurred if these precautions are not obeyed.

CAUTION

... Describes precautions to be observed where there is a risk of damage to the instrument.

NOTE

... States information that is important for proper operation of the instrument.

WHEN THE INSTRUMENT HAS ARRIVED

The instrument is strictly factory inspected. After it has arrived, however, check the quantities of accessories, etc. and appearance and operation of the instrument to make sure nothing is wrong.

If some accessories are missing or the operation is poor, contact the nearest service agent given on the back cover of the manual.

1. ACCESSORIES


The instrument is furnished with accessories given in Figure 1 and Table 1. Check the quantities, etc. against them.

• Checking Model and Specifications of the 2533E

Model	Suffix Code	Specifications
2533E31		Single-Phase, AC
2533E32		Three-Phase 3-Wire, AC
2533E33		Three-Phase 4-Wire, AC
2533E41		Single-Phase, DC/AC
2533E42		Three-Phase 3-Wire, DC/AC
2533E43		Three-Phase 4-Wire, DC/AC
	-C1	GP-IB interface
	-C2	RS-232-C interface
	-1	Rated supply voltage setting: 100 VAC (50/60 Hz)
	-3	Rated supply voltage setting: 115 VAC (50/60 Hz)
	-5	Rated supply voltage setting: 200 VAC (50/60 Hz)
	-7	Rated supply voltage setting: 230 VAC (50/60 Hz)
	-M	UL/CSA standard power cord + 3-pin to 2-pin adapter (Part number: A1253JZ)
	-D	UL/CSA standard power cord (Rating: 125 VAC, 7 A) (Part Number: A1006WD)
	-F	VDE standard power cord (Rating: 125 VAC, 10 A) (Part Number: A1009WD)
	-R	VDE standard power cord (Rating: 240 VAC, 10 A) (Part Number: A1024WD)
	-J	BS standard power cord (Rating: 250 VAC, 5 A) (Part Number: A1023WD)
	/FREQ	
	/INTEG	

• Check Accessories

The following accessories are supplied with the 2533E.



Number	Name		Part Number	Quantity	Remarks
①	Power fuse	For 100 V range systems	A9050KF	1	• Should match the rated supply voltage specified by the suffix code (250 V, 1 A time-lag fuse, for 100 V range systems; 250 V, 0.5 A time-lag fuse, for 200 V range systems). • The spare fuse is stored inside the power fuse holder on the rear panel.
		For 200 V range systems	A9049KF		
②	Remote control connector		A 1005JD	1	Connector for use on the cable to be connected to the remote-control/analog-output connector.
③	Power cord (+3-pin to 2-pin adapter if applicable)		Indicated on preceding page	1	Type of cord is specified by suffix code.
④	Rack mount adapter		B9564EL	2	
⑤	Dry cell		A9005ED	2	R6P
⑥	User's manual		IM 2553E-01E IM 2553E-51E or IM 2553E-70E	1	Interface

2. SELF-TEST WHEN TURNING ON POWER

The instrument incorporates a self-test function. It is performed automatically by on power up. Examine the unit for shipping damage or failures during self-test.

<Self-test procedure>

(1) Connecting Power

- 1) Make sure the power switch of the instrument is turned OFF, and engage the furnished power cord with the power connector on the rear panel of the instrument shown in Figure 2.
- 2) Plug the unit into a power receptacle.

CAUTIONS

- If the power voltage is wrong, the instrument will be damaged. Be sure to use power in the range specified on the right of the power connector.
- Ensure the power voltage change switch located on the right of the connector shown in Figure 2 is in the proper position, down when power voltage is 100 V (200 V) according to the label, or up when 115 V (230 V).
- If change the power voltage, turn off the power switch.

(2) Turning ON Power Switch

Turning ON the power switch starts the incorporated test program.

The tested items are RAM memory check (write, read) and ROM sum check. The time required is about 1 second.




Figure 2.

(3) Judging Results of Self-Test**1) If Test Results are Normal**

When the aforementioned RAM and ROM self test complete successfully, the model, system configuration and version No. are displayed for several seconds in a format shown in Figure 3, thereby readying the instrument for measurement.

From the display of this system configuration, the number of input elements mounted on the instrument and types of options are shown in section 4-1 2. **Hardware Configuration.**




Figure 3.

2) If Test Results are Abnormal

If results of the self tests are abnormal, the test is suspended, and the following error code is displayed on DISPLAY C.


NOTE

If any of the above code is displayed, the instrument will not work properly. Immediately turn OFF the power switch, and contact the service agent specifying the model name, serial number and displayed error code.


- When RAM is faulty



- When ROM0 is faulty



- When ROM1 is faulty



1. OUTLINE OF PRODUCT

1-1. General

The manual describes how to operate the Digital Power Meters 2533E32 (three-phase three-wire), 2533E42 (three-phase three-wire), 2533E33 (three-phase four-wire) and 2533E43 (three-phase four-wire).

Two types of meters are available which measure AC and DC/AC. AC meters measure AC voltage/current and AC power in a single-phase circuit or three-phase circuit. DC/AC meters measure DC current and AC current in a single-phase or three-phase circuit. Voltage, current and power—that AC is superimposed on DC—are also measured. Computation functions are included to totalize apparent power, reactive power, power factor and frequency. The frequency ranges 10 Hz to 30 kHz, and distorted wave of inverter can be measured accurately.

1-2. Features

◎ Simultaneous Display of 3 Measured Values

Three values among measured or computed values are simultaneously displayed: voltage, current, and power or apparent power or reactive power of single phase to three-phase three-wire or three-phase four-wire circuits.

◎ High Precision

The voltage, current and power can be measured with high accuracy: $\pm(0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ (for AC meter 2533E3□) $\pm(0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ (for DC/AC meter 2533E4□).

◎ Wide Band of DC 10 Hz to 30 kHz

Having a DC range and frequency range of 10 Hz to 30 kHz, DC/AC meters measure DC current and AC current in a single-phase or three-phase circuit, voltage, current and power—that AC is superimposed on DC—are also measured, the instrument is best suited for measuring power of distorted wave and different inverters.

◎ Abundant Computing Functions are Incorporated

Line voltage or phase voltage mean value, phase current mean value, apparent power, reactive power, power factor, etc. can be computed.

◎ PT and CT Scaling

Even when PT or CT is externally mounted, the voltage, current, power, etc. can directly be read through scaling.

◎ Analog Output Is Standard Equipped

Analog output can output simultaneously up to twelve (three-phase four-wire) or nine (three-phase three-wire) signals.

◎ GP-IB and RS-232-C Interfaces

For data communications, the GP-IB or RS-232-C interface is available. Full remote control is available for data output and range, function, etc. from external.

◎ Integration and Frequency Measuring Function (Option)

Current and power integrating function, and source frequency measuring function can be provided.

1-3. Designations and Functions




Figure 1-1. Front Panel

① Power ON/OFF switch

Turn ON/OFF power.

ON at and OFF at .

② Wiring Change Key:

Changes to three-phase three-wire or three-phase four-wire.

The key lamp is lit when set to three-phase three-wire system. Effective only for the model for three-phase four-wire system (2533 13 and 2533 23). It stays lit on the model for three-phase three-wire system (2533 12 and 2533 22).

③ Voltage Mode Change Key:

Selects voltage display mode whether RMS value or MEAN (average) value is displayed. When RMS value is displayed, the key lamp is lit.

When the DC/AC model is used to measure a DC voltage signal without AC components, select RMS mode. If the above voltage signal is measured in MEAN mode, that DC signal is assumed to be a sinusoidal AC voltage signal and rectified, and its effective value is displayed with the measured value multiplied by 1.1107.

④ Filter ON (SLOW)/OFF (FAST) Key:

When a low frequency voltage or current is measured and noise is superposed or the display fluctuates, turn ON the filter. When ON, the key lamp is lit. Turning ON the filter permits a stable measurement even if low frequency ripples are superposed.

⑤ Averaging Key:

By digital computation of A-D converted value, an input filter effect is obtained. When averaging is ON, the key lamp is lit.

⑥ Scaling Key:

Turns ON/OFF a scaling function. When the scaling function is on, the key lamp is lit.

⑦ Hold and Trigger Keys:

Pressing the hold key stops a measurement action and, on the digital display, the value measured just before the pressing is held. If the display function is changed when in hold mode, specified data are displayed when data are present or, when data is absent, "(—) ————" is displayed. The analog output is a value proportional to input regardless of the hold.

When in hold mode, every press of the trigger key updates the measured value.

⑧ Voltage Range Change Keys

The voltage range is changed over.

Pressing key changes to the next lower voltage range, and pressing key changes to the next upper range. By pressing key, the voltage range is automatically changed. At this time, AUTO key lamp is lit. When in automatic range, and keys are overridden. Voltage ranges are 30/60/100/150/300/600 V.

⑨ Voltage Peak Over Display Lamp

If the peak value of a voltage wave has exceeded about 250% of the set range, PEAK OVER display lamp located on the left of **AUTO** key comes on.

⑩ Current Range Change Keys

Function of **▲**, **▼** and **AUTO** keys is the same as for voltage range. The current ranges are 0.5*/1/2/5/10/20 A.

*DC/AC meter does not cover 0.5A range.

⑪ Current Peak Over Display Lamp

If the current peak value has exceeded about 350% of the set range, PEAK OVER display lamp comes on.

⑫ Parameter Setting Keys

SCALING key allows to set PT ratio, CT ratio, SCALING FACTOR. If you have the optional integration function, the **TIMER** key can set the integration time.

Pressing **SCALING** key lights up the key lamp. DISPLAY A, B and C display the PT ratio, CT ratio and SCALING FACTOR, respectively.

The most significant digit of DISPLAY A flashes, thereby indicating data in that place is changeable.

The flashing digit can be moved to the right by **>** key. The flashing digit displayed can be changed by **▲** key to 1 → 2 → ... → 9 → 0 → 1 ...

■ key moves the decimal point to the right. The displayed value is set by **ENTER** key. Pressing **TIMER** key lights the lamp, whereby the integrated time is settable on DISPLAY C. The keys are overridden for a model not provided with the optional function.

⑬ Integrator Key (option)

Used for power or current integration. The keys are overridden for a model not provided with the optional function.

Pressing **START** key lights up the lamp, commencing an integration.

Pressing **STOP** key lights the lamp, stopping the integration.

RESET key clears the integrated value when the integration has stopped.

⑭ Function Keys (DISPLAY A)

V key selects voltage, **A**, current, and **W**, power. The lamp of the selected function comes on.

⑮ Element Select Keys (DISPLAY A, B, C)

1, **2** and **3** are keys for selecting respective elements when you have a three phases unit.

Σ allows to display the power sum of all phases for power, or an average of all phases for voltage or current, and the lamp for the selected element key comes on.

⑯ Function Keys (DISPLAY B)

V key selects voltage, **A**, current, and **W**, power.

INTEG TIME key is used for displaying integrated time in case integrator is opted. The lamp for the selected function key comes on. The keys are overridden for a model not provided with the optional function.

⑰ Function Keys (DISPLAY C)

V key selects voltage, **A**, current, **W**, power, **var**, reactive power, **VA**, apparent power, **PF**, power factor, **Hz**, frequency, **Wh**, integrated power, and **Ah**, integrated current. The lamp of a selected function key comes on. But, **Hz**, **Wh** and **Ah** keys are overridden for a model not provided with the optional function.

⑱ Battery Display Lamp

Comes on when the memory backup battery is exhausted.

⑲ Sample Display Lamp

The lamp comes on about every 0.4 second. Every time it lights, the displayed data is updated. It remains off at a hold mode.

⑳ Remote Control Display Lamp

Lit in remote control mode with GP-IB interface (option).

㉑ Local/Demag Key: LOCAL/DEMAG (For DC/AC models), LOCAL (For AC models)

In remote mode with GP-IB, pressing this key cancels the remote mode.

For DC/AC models, in local mode, use this key before starting measurement to demagnetize the DC-CT core if an excessive input was applied. To demagnetize the core correctly, use this key without applying a DC input.




Figure 1-2. For Three-Phase Three-Wire System




Figure 1-3. For Three-Phase Four-Wire System

Rear panel**① Power Connector**

The furnished power cord is connected.

② Power Voltage Change Switch

The switch is changed to 100 V or 115 V according to the power voltage. With 200 V series, 200 V and 230 V are changed over.

③ Power Fuse

When the power voltage is 100 V series, a time lag fuse of 250 V, 1 A (A9050KF) is used. With 200 V series, a time lag fuse of 250 V, 0.5 A (A9049KF) is used.

④ Panel Set Data Protecting Battery

Two R6P battery are used. New cells protect panel set operating conditions for about one year.

⑤ Function Ground Terminal

This ground terminal cannot be used as protective ground terminal.

Use this terminal for grounding for the functional purpose.

⑥ Voltage Input Terminal**⑦ Current Input Terminal**

Voltage and current input terminals are provided. Once the voltage and current input terminals are connected, voltage and current ranges may be changed by the front panel keys, after power up.

⑧ Wiring Instruction Plate

A wiring diagram is shown for each particular model.

⑨ Remote Control/Analog Output Connector

A connector for starting measurement by an external contact closure command and taking out input voltage, current waveform, and voltage, current and effective power analog output.

⑩ Integrator/Remote Control/Analog Output Connector (Option/INTEG)

An external contact closure command performs start/stop and reset control of integrator. Also used to take out integrated value and VA, PF, var, Hz and D-A converter.

⑪ GP-IB Connector**⑫ Address Setting Switch****⑬ Mode Setting Switch**

(TALK ONLY/ADDRESSABLE).

* For RS-232-C, RS-232-C connector and DIP switches —for data mode, data format and transfer rate settings—are added.

} GP-IB

1-4. Specifications

Display: LED (light-emitting diode)

Display Mode (3 displays):

Mode	Max. Display	Display Item
A	±99999	V, A, W (1, 2, 3, Σ for each)*
B	±99999	V, A, W (1, 2, 3, Σ for each)* integration lapse (option)
C	±99999 (±999999 Wh, Ah)	V, A, W, VA, var, PF, (Hz, Wh, Ah ... option, 1, 2, 3, Σ for each)*

*: 1, 3, Σ for three-phase three-wire

Unit: m, k, M, V, A, W, VA, var, Hz h, ►

Function Change: display A, B, C can be changed independently (except VA, var, PF)

(mode is changed by GP-IB or RS-232-C interface)

Sample Rate: approx. 2.5 samples/s

Range Change: manual, auto and external control (GP-IB ... option) change all phase to the same ranges independently for V and A

Auto Range Change: by RMS or MEAN value in case of V, RMS value in case of A

Demagnetizing: Demagnetizes DC-CT core by pressing the  key in local mode, or receiving a DM command in remote or local mode. Demagnetizing time is approx. 5 seconds.

Effective Input Range: 10 to 110% of rated value (range)

Response Time: approx. 0.4 s (time required for analog value to reach specified accuracy at change of 30→100% or 100→30% when filter is OFF). Approx. 2 s when filter is ON.

Data Output: wave output; v_1 , v_2 , v_3 , i_1 , i_2 , i_3 (for monitor)

Analog output:

$$V_1, V_2, V_3, \frac{V_1+V_3}{2} \text{ or } \frac{V_1+V_2+V_3}{3}$$

$$A_1, A_2, A_3, \frac{A_1+A_3}{2} \text{ or } \frac{V_1+V_2+V_3}{3}$$

$$W_1+W_2+W_3, W_1+W_3 \text{ or } W_1+W_2+W_3.$$

12 kinds output simultaneously at three-phase four-wire

9 kinds output simultaneously at three-phase three-wire

D-A output: one of VA, var, PF, Wh, Ah, Hz (data indicated on display C)

GP-IB or RS-232-C interface: display data and measurement data

External Control: measurement sample start, A-D BUSY (standard), integrator (option) start, stop and reset

Operating temperature and humidity ranges: 5 to 40°C (23 to 104°F), 20 to 80% R.H.

Storage Temperature Range: -10 to 50°C (14 to 122°F) (non-condensing)

Warmup Time: approx. 30 min (until all specifications are satisfied)

Insulation Resistance: Use a 500 V insulation resistance tester. At least 50 MΩ between: (input terminal and case, input and output terminals, voltage and current terminals, input terminal, output terminal, case and power supply terminal)

Dielectric Strength: 3,000 V AC, 50/60 Hz, 1 min (input terminal and case, input and output terminals, voltage and current terminals), 1,500 V AC, 50/60 Hz, 1 min. (input and output terminals, case and power supply terminals)

Source: 100 or 115 V ±10% AC, 48 to 63 Hz (200 V series to be specified)

Power Consumption: approx. 35 VA

External Dimensions: approx. 149×444×364 mm (5-7/8"×17-1/2"×14-5/16")

Weight: approx. 14 kg (31 lbs.) (for AC meter)
approx. 16 kg (35 lbs.) (for DC/AC meter)

Accessories: power cord ... 1. Fuse ... 2 (1 A for 100 V series, 0.5 A for 200 V series). Connector ... 1. Mounting fixture ... 1 set. Dry cells (R6P) ... 2. Instruction manual ... 2 copies (separate manuals for options).

Input section

Item	Input	Voltage	Current
Type of input	AC	Direct input (CT isolation after changing range)	CT isolation (secondary switching)
	DC/AC	Direct input (DC-CT isolated after changing range)	DC-CT isolated (secondary switching)
Rated value (range)	AC	30/60/150/300/600 V	0.5/1/2/5/10/20 A
	DC/AC		1/2/5/10/20 A
Frequency range	AC	10 Hz to 30 kHz	10 Hz to 30 kHz
	DC/AC	DC, 10 Hz to 30 kHz	DC, 10 Hz to 30 kHz
Max. allowable input for 1 s		Peak 3.5 times range or 1,400 V whichever smaller	Peak 10 times range or 70 A, whichever smaller
Max. continuous allowable input (at 50/60 Hz)		Peak 1,000 V or rms value 2 times range, whichever smaller	Peak 50 A or rms value 3 times range, whichever smaller
Instrument loss	AC DC/AC	Input resistance approx. 1 MΩ (all ranges)	At 50 Hz, 2 mΩ in all ranges
Max. continuous common mode voltage, 50/60 Hz		1,000 Vrms	1,000 Vrms
Influence by common mode voltage at 50/60 Hz		Less than ±0.025% of range (input terminals shorted, 1,000 V applied to input-case)	Same as voltage (input terminal open)

*DC/AC meters do not cover 0.5 A range.

Measurement Functions

Measurement Functions		Voltage	Current	Power
Item				
Principle		Change of mean value rectification and true RMS by LOG-anti LOG	True RMS by LOG-anti LOG	PWM time division multiplication
Measured item	Three-phase three-wire	$V_1, V_3, \frac{V_1+V_3}{2} (\Sigma)$	$A_1, A_3, \frac{A_1+A_3}{2} (\Sigma)$	$W_1, W_3, W_1+W_3(\Sigma)$
	Three-phase four-wire	$V_1, V_2, V_3, \frac{V_1+V_2+V_3}{3} (\Sigma)$	$A_1, A_2, A_3, \frac{A_1+A_2+A_3}{3} (\Sigma)$	$W_1, W_2, W_3, W_1+W_2+W_3(\Sigma)$
Measurement frequency	AC	10 Hz to 30 kHz	10 Hz to 30 kHz	10 Hz to 30 kHz
	DC/AC	DC, 10 Hz to 30 kHz	DC, 10 Hz to 30 kHz	DC, 10 Hz to 30 kHz
Crest factor	AC	Max. 3	Max. 2	Same as these described in voltage and current column.
	DC/AC		Max. 3 or 50 A (peak)	
Accuracy	AC	10 to 20 Hz $\pm(0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 20 to 45 Hz $\pm(0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 45 to 66 Hz $\pm(0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 66 Hz to 2 kHz $\pm(0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 2 k to 10 kHz $\pm 1.0\% \text{ of range}$ 10 k to 20 kHz $\pm 1.5\% \text{ of range}$ 20 k to 30 kHz $\pm 2.0\% \text{ of range}$ (at input 10 to 110%)	10 to 20 Hz $\pm(0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 20 to 45 Hz $\pm(0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 45 Hz to 66 Hz $\pm(0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 66 Hz to 2 kHz $\pm(0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 2 k to 10 kHz $\pm 1.0\% \text{ of range}$ 10 k to 20 kHz $\pm 1.5\% \text{ of range}$ 20 k to 30 kHz $\pm 2.0\% \text{ of range}$ (at input 10 to 110%)	At $\cos \phi = 1$ 10 to 20 Hz $\pm(0.3\% \text{ of rdg} + 0.4\% \text{ of range})$ 20 to 45 Hz $\pm(0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 45 to 66 Hz 400 Hz $\pm(0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 66 Hz to 2 kHz $\pm(0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 2 k to 10 kHz $\pm 1.0\% \text{ of range}$ 10 k to 20 kHz $\pm 2.0\% \text{ of range}$ 20 k to 30 kHz $\pm 3.0\% \text{ of range}$
	DC/AC	DC: $\pm(0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 10 to 20 Hz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 20 to 45 Hz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 45 to 66 Hz $\pm(0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 66 Hz to 2 kHz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 2 k to 10 kHz $\pm 1.0\% \text{ of range}$ 10 k to 20 kHz $\pm 1.5\% \text{ of range}$ 20 k to 30 kHz $\pm 2.0\% \text{ of range}$ (at input 10 to 110%)	DC: $\pm(0.1\% \text{ of rdg} + 0.2\% \text{ of range} + 3 \text{ mA})$ 10 to 20 Hz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 20 to 45 Hz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 45 to 66 Hz $\pm(0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 66 Hz to 2 kHz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 2 k to 10 kHz $\pm 1.0\% \text{ of range}$ 10 k to 20 kHz $\pm 1.5\% \text{ of range}$ 20 k to 30 kHz $\pm 2.0\% \text{ of range}$ (at input 10 to 110%)	At $\cos \phi = 1$ DC: $\pm(0.1\% \text{ of rdg} + 0.3\% \text{ of range})$ 10 to 20 Hz $\pm(0.3\% \text{ of rdg} + 0.4\% \text{ of range})$ 20 to 45 Hz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 45 to 66 Hz 400 Hz $\pm(0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 66 Hz to 2 kHz $\pm(0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 2 k to 10 kHz $\pm 1.0\% \text{ of range}$ 10 k to 20 kHz $\pm 2.0\% \text{ of range}$ 20 k to 30 kHz $\pm 3.0\% \text{ of range}$
Influence by power factor		—	—	Within 50/60 Hz $\pm 0.5\%$ of rdg at $\cos \phi = 0.5$
Accuracy (analog output) at same conditions as for display		Add 0.05% of range to display accuracy shown above.		
Temperature coefficient 5 to 20°C (41 to 68°F), 26 to 40°C (79 to 104°F)		Less than $\pm 0.03\%$ of range/°C (Less than $\pm 0.02\%$ of range/°F)	Same as voltage	Same as voltage

* Accuracy within one year after calibration: Compared with the 90 days accuracy, add (total error) $\times 0.5$

Computing Functions**Apparent Power, Reactive Power and Power Factor Computations**

Computing Function		Apparent Power (VA)	Reactive Power (var)	Power Factor (PF)
Item				
Arithmetic expression	1 to 3 (each part)	$V_i \times A_i$	$(V_i \times A_i)^2 - W_i^2$	$\frac{W_i}{V_i \times A_i}$
	Σ (three-phase three-wire)	$\frac{V_1 + V_3}{2} \times \frac{A_1 + A_3}{2} \times \sqrt{3}$	$\frac{\sqrt{\left(\frac{V_1 + V_2}{2} \times \frac{A_1 + A_3}{2} \times \sqrt{3}\right)^2} - (W_1 + W_3)^2}{- (W_1 + W_3)^2}$	$\frac{W_1 + W_3}{\frac{V_1 + V_3}{2} \times \frac{A_1 + A_3}{2} \times \sqrt{3}}$
	Σ (three-phase four-wire)	$\frac{V_1 + V_2 + V_3}{3} \times \frac{A_1 + A_2 + A_3}{3} \times 3$	$\frac{\sqrt{\left(\frac{V_1 + V_2 + V_3}{3} \times \frac{A_1 + A_2 + A_3}{3} \times 3\right)^2} - (W_1 + W_2 + W_3)^2}{- (W_1 + W_2 + W_3)^2}$	$\frac{W_1 + W_2 + W_3}{\frac{V_1 + V_2 + V_3}{3} \times \frac{A_1 + A_2 + A_3}{3} \times 3}$
Computation range		Rated value depends on V, A ranges (F.S. resolution same as corresponding W range)	Same as apparent power	-1 to 0 to +1 (10 to 110% of rating for V and A)
Computation accuracy with respect to value calculated from measured value (V, A, W)		$\pm 0.05\%$ of rated value (VA)	$\pm 0.05\%$ of rated value (var)	± 0.001

*Reactive power (var), apparent power (VA) and power factor (PF) of the instrument are obtained by digital computation from voltage, current, effective power, etc.

*When distorted waveshapes are measured, differential in measured values using this instrument and other instrument with different principle of measurement may occur.

Scaling Function

Each measured value multiplied by PT ratio, CT ratio, SCALING FACTOR or others is displayed (unit is changed automatically)

Effective Digit: selected automatically according to effective digit of voltage and current ranges

Setting Range: 0.0001 to 10000

Set Value: DISPLAY A settable for PT ratio, DISPLAY B for CT ratio, DISPLAY C for scaling factor

Averaging Function

Principle: exponential averaging with attenuation factor $K=8$

■ GP-IB Interface

Electrical, Mechanical Specifications: conform to IEEE Std 488-1978

Functional Specifications: SH1, AH1, T5, L4, SR1, RL1, PP0, DC1, DT1, C0
(ADDRESSABLE/TALK ONLY)

■ RS-232-C Interface

Data Transmission System: Start-stop system

Data Transmission Rate: 75, 150, 300, 600, 1200, 2400, 4800, 9600 bps.

Optional Specifications**■ Frequency Measurement (/FRQ)**

Measurement Principle: reciprocal

Measurement Frequency Range: 8 Hz to 200 kHz (filter OFF), 2 to 200 Hz (filter ON)

Accuracy: $\pm(0.1\% + 1 \text{ digit})$

IM 2533E-03E

Min. Voltage and Current Input Sensitivity: $\pm 10\%$ of F.S.

Display Range: 2.000 Hz to 240.0 kHz (4 digits)

Sampling Rate: 400 ms (filter OFF), 1.6 s (filter ON)

Measurement Input: V1 or A1

■ Integrator Function (/INTEG)

Max. Display: ± 999999 (6 digits)

Integration Time: 999 h

Display: Ah or Wh by DISPLAY C

Timer: integration can automatically be stopped by timer setting. Set value ... 000 h:01 min to 999 h:00 min (timer OFF at 000 h:00 min).

Lapse of Time: lapse of time after integration start can be indicated as 0 to 999 h:00 min by display B

Count Over: if integrated value over ranges, lapse of time is held and control stops

Accuracy: $\pm$ (mainframe accuracy $+0.02\%$ of rdg $+1$ digit)

Temperature Characteristics: $\pm 0.025\%$ of range/ $^{\circ}\text{C}$ (± 0.045 of range/ $^{\circ}\text{F}$)

Timer Accuracy: $\pm 0.02\%$

Remote Control: start, stop and reset control are made by external contact closure command

■ D-A Converter Function

Principle: 16 bit PWM system, D-A converter

Output Range: $(-7.5 \text{ to } +7.5\text{V})$ rating: 5V/F.S.

Accuracy: mainframe accuracy $+0.1\%$ of F.S.

Temperature Characteristics: $\pm 0.02\%/^{\circ}\text{C}$ ($\pm 0.036\%/^{\circ}\text{F}$)

Output Contents: one of Wh, Ah, var, VA, PF and Hz (data specified at DISPLAY C)

Sampling Rate: 400 ms

1-5. Operating Principle

Figure 1-4 is a block diagram for the digital power meter of three-phase four-wire system. It consists of input section, RMS board, MPX board, A-D board, CPU board, etc.

In the voltage input circuit adopted for the input section, the input voltage is changed to a constant current by voltage divider and preamp and is then isolated by a CT. In the current input circuit, the CT primary winding is fixed and the secondary load and preamp gain are changed over. With this, changing the current range does not open the primary current circuit, permitting safe changes, and remote control can be attained by using GP-IB or RS-232C interface.

On RMS board, the voltage output is subjected to true rms computation by log-antilog method or mean value rectification rms value computation. The current output is subjected to true rms computation by log-antilog. For power measurement, the multiplier circuit resorts to a PWM (pulse width modulation) time division system. To ensure wide bandwidth and high accuracy, the clock frequency adopted is 125 kHz and, for a switching element, a high speed MOS device is used.

Output from RMS board passes through MPX board, and enters A-D converter of 16 bit PWM system, where it is converted to a digital value. On MPX board, outputs from different input sections are connected and can be selected to match the display mode.

CPU board is centered around an 8 bit 8085. Here, A-D converter control, display section control and also apparent power, reactive power, power factor, PT ratio, CT ratio scaling and other computations are carried out.

Analog output, voltage and current waveform from different input sections as well as voltage, current and power converted into DC voltages are available.

Three-phase three-wire system is three-phase four-wire system minus input section 2 and the network related to it.










Figure 1-4. Block Diagram of Three-Phase System

1-6. External Dimensions

Unit: mm (inch)



2. HANDLING

2-1. General Operating Procedure

A general operating procedure of the instrument is illustrated in the form of a flow chart. The description is made almost in the illustrated sequence.




Figure 2-1.

2-2. Installing and Replacing Battery

(1) Installing Battery (First Time)

1) On the instrument, "panel setting information protective dry cells" are installed for backup of setting information in case of a power failure or when the power switch is turned OFF. The battery is housed at the upper right corner on the rear of the mainframe as depicted in Figure 2-2.




Figure 2-2.

2) By pulling the knob located at the upper middle of the battery cover shown in Figure 2-2, the cover is unlocked and can be taken out of the mainframe.

3) In the middle of the internal battery case, a red ribbon is mounted. As shown in Figure 2-3, mount two furnished dry cells (R6P) on top of the ribbon.

Observe proper polarity when installing the batteries.




Figure 2-3.

4) As depicted in Figure 2-4, fold back the excess of ribbon upward, put the cover in place and push the knob to lock.

Take care so the ribbon end does not show outside the case.




Figure 2-4.

5) The battery life is about one year at a normal operating status. When the battery voltage becomes lower than specified, BATTERY indicator lamp on the upper left corner of the front panel comes on, thereby indicating the battery must be replaced.

(2) Replacing Battery

- 1) If BATTERY indicator lamp stated in 5) above is lit, immediately prepare two new dry cells.
- 2) Referring (1) 2), remove the cover from the housing.
- 3) Pull the red ribbon and remove the old cells.
- 4) Thereafter, replace the cells in the procedure given in (1) 3) and 4).
- 5) **Replace the cells with 2533E turned ON so as not to lose the setting information.**

If the cells are replaced with power OFF, the set data is destroyed and the control return to a default mode to be described in section 2-5.

Note, however, that in the default mode, the voltage and current ranges are maximum with 600 V and 20 A. Therefore, turning ON does not damage the instrument.

CAUTIONS

1. Replace with cells of the same manufacturer, where possible.
2. Replace two cells at a time and refrain from using new and old cells together.
3. Refrain from using cells whose history is unknown.
4. Do not discard old cells together with ordinary garbage.

(3) Setting Information Backed Up By Battery

Table 2-1 shows setting information backed up by the “panel setting information protective dry cells” installed as explained in (1).

Table 2-1.

Display Mode	DISPLAY A	V A W				Upper/lower combined setting	
		1 2 3 Σ					
	DISPLAY B	V A W INTEG TIME				Upper/lower combined setting	
		1 2 3 Σ					
	DISPLAY C	V A W var VA PF Hz Wh Ah					Upper/lower combined setting
		1 2 3 Σ					
Measurement Mode	WIRING			Wiring section (3φ3W/3φ4W)			
	VOLT			Voltage section (RMS/MEAN)			
	FILTER AVG SCALING			各々の設定状態 (ON/OFF)			
Sampling Mode	HOLD			Sampling section (ON/OFF)			
Measurement Range	VOLTAGE RANGE (V)			Setting range			
	AUTO			Range section (ON/OFF)			
	CURRENT RANGE (A)			Setting range			
	AUTO			Range section (ON/OFF)			
Scaling Value	DISPLAY A	SCALING		PT ratio set value			
	DISPLAY B			CT ratio set value			
	DISPLAY C			SCALING FACTOR set value			
Timer Setting	TIMER			Set value			

- Notes:**
1. In the display mode, ☐ Hz of DISPLAY C is effective only when the frequency measurement function (option code: /FRQ) is installed.
 2. In the display mode, ☐ Wh and ☐ Ah of DISPLAY C and ☐ TIMER of the timer setting are effective only when the integrator function (option code: /INTEG) is installed.

3. When GP-IB or RS-232-C interface is installed, the following interface-related parameters are not backed up:
 - service request mask: IM* *
 - BLOCK output time delimiter: DS* (GP-IB only)

2-3. Installation

The instrument is available as a desk top type, or the like or a rack mount type with the furnished adapter.

(1) Desk Top Type

The instrument can be installed horizontal or tilted on a table.

To tilt the instrument, lift the front and pull the stand located on the instrument bottom. It is locked in a position almost perpendicular with respect to the bottom surface. To unlock, push back the stand while pushing inward on the right and left legs of the stand.




Figure 2-5.

(2) Rack Mount Type

For use as a rack mount type, the supplied adapter must be mounted.

<Mounting Procedure>

- ① Remove the rubber covers from the sides of the mainframe shown in Figure 2-6.
- ② Loosen each right and left 2 countersunk screws from the locations where the rubber covers were removed.
- ③ Attach the adapter with the countersunk screws loosened in ②.
- ④ Remove the four legs from the mainframe sides with a flathead screwdriver.
- ⑤ Mount the mainframe on the rack.
 - ◎ When installing, be sure to add a support from underneath.




Figure 2-6.

2-4. Wiring Procedure

This section describes the wiring method for three-phase power— 2533E32 and 2533E42 (three-phase three-wire), and 2533E33 and 2533E43 (three-phase four-wire). Measurements are available for the two versions as given in Table 2-2. According to the particular measurement, refer to the wiring procedure stated below. In the table, mark ⊙ indicates the factory set status, and mark ○ indicates an applied measurement process.

On the wiring diagram, both voltage and current sides are connected to do power measurements. When measuring voltage or current only, connecting the voltage of current only, will suffice.

Table 2-2.

Wiring System	No. of Input Elements (EL) Used	2533E32 2533E42	2533E33 2533E43	Refer to
Single-phase Two-wire	1	○	○	2-4-1.
Three-phase Three-wire	2	⊙	⊙	2-4-2.
Single-phase Three-wire	2	○	○	2-4-3.
Three-phase Four-wire	3	×	⊙	2-4-4.
Three-phase Three-wire	3	×	○	2-4-5.

WARNING

- Before connecting the line under test to the instrument, turn OFF the power switch of the load. Take utmost care not to connect a voltage circuit to the current input terminal, or a current circuit to the voltage input terminal. Wrong connection is not only dangerous to the human body but also might burn the instrument.
- Use connecting wires of proper size and gage with respect to the voltage and current to be measured.
- Although the rear panel, etc. of the input element used on the instrument are so designed as to ensure safety, it is very dangerous to remove the connecting wires with SOURCE side turned on. Be sure to turn OFF the input signal before removing the connecting wires.

CAUTION

Whether the power switch is turned ON or OFF, applying voltage or current beyond the maximum continuous or momentary allowable input indicated in the Specifications might damage the instrument.

NOTES

- In a power measurements, large current and voltage and current containing high frequency components are handled. Wire inputs with regard to about their mutual interference and countermeasure for noise.

As required, separate, twist or shield the wiring.

- Influence by a residual current may occur if the wiring resistance is lower than 40 mΩ when a high sensitivity range is used for current measurement.
- The terminal $\perp$ located on the lower right corner of the rear panel is the function ground terminal. This ground terminal cannot be used as protective ground terminal. Use this terminal for grounding for the functional purpose.

2-4-1. Power Measurement of Single-Phase Two-Wire (1 ϕ 2W) System

(1) When both Voltage and Current are Within Specified Measurement Ranges

When both voltage and current are within the specified measurement ranges for the instrument, select one of the input elements incorporated in the instrument and, as shown in the wiring diagram in the middle of the rear panel, or in Figure 2-7, securely connect SOURCE and LOAD wires to the voltage and current terminals on the rear of the input element. In Figure 2-7, the thicker line indicates the current circuit, and the thinner line indicates the voltage circuit.

With this wiring, the digital display show the measured value as it is.

At this time, 2533E 32, E 42 are usable as two single phase power meters, and 2533E 33, E 42, as three power meters.




Figure 2-7.

(2) When both Voltage and Current Exceed Specified Measurement Ranges

The maximum measurement ranges of the input element are 600 V for voltage, and 20 A for current.

When it is desired to measure a greater voltage or current, connect an external potential transformer (PT) and current transformer (CT) as shown in Figure 2-8.

Note: The frequency characteristics and phase characteristics of the external PT and CT influence the measured value.




Figure 2-8.

Generally, PT secondary is 110 V or 150 V, and CT secondary is 5 A. Select appropriate primary ranges according to the voltage and current to be measured. PTs and CTs in Tables 2-5 and 2-6 (related products) are available from us. Their use combined with this instrument considerably widens the voltage and current measurement ranges.

<Examples of Calculation When Using PT and CT>

- (1) **Voltage Measurement**=instrument's voltage reading×PT ratio

Example: Instrument's voltage

reading 100.00 V
PT ratio 3300/110=30
Measured voltage .. 100 V×30=3kV

- (2) **Current Measurement**=instrument's current reading×CT ratio

Example: Instrument's current

reading 4.000 A
CT ratio 50/5=10
Measured current .. 4 A×10=40 A

- (3) **Power Measurement**=instrument's power reading×PT ratio×CT ratio

Example: Instrument's power

reading 350.0 W
PT ratio 3300/110=30
CT ratio 50/5=10
Measured power ... 350 W×30×10=105 kW

- When it is desired to directly read on the display the values measured as shown above, set the PT and CT transformation ratios by scaling.

For details of scaling, refer to section 2-10 Setting Scaling (SCALING) Factor.

WARNING

When using an external current transformer, its secondary must not be opened at an energized mode. If opened, a high voltage would appear on the current transformer secondary which is very dangerous.

NOTES

- The instrument is so designed that, by changing the range by the range change key  or  on the front panel, the secondary of the incorporated current transformer is not opened. Therefore, the range may be changed in an energized mode.
- When measuring low power factor wattage, a slight phase error from a potential or current transformer influences the measured power considerably. Be aware of it when the power must be measured accurately.

2-4-2. Power Measurement of Three-Phase Three-Wire (3 ϕ 3W) System

(1) When both Voltage and Current are Within Specified Measurement Ranges

When both voltage and current are within the measurement ranges specified for the instrument, securely connect SOURCE and LOAD wires to the voltage and current terminals on the rear of two input elements as shown in the wiring diagram in the middle of the rear panel or in Figure 2-9. The thicker line indicates the current circuit, and the thinner line indicates the voltage circuit.

With this wiring, the indicated items and their details are as shown in the column of three-phase three-wire system (measurement of 2 voltages, 2 currents) in Table 2-3.




Figure 2-9.

Table 2-3. Wiring, Indicated Items and Their Details

Wiring Indicated Item		Single-Phase Two-Wire (1 ϕ 2W)	Single-Phase Three-Wire (1 ϕ 3W) *1)	Three-Phase Three-Wire (Measurement of 2 Voltages, 2 Currents, 3 ϕ 3W)	Three-Phase Three-Wire (Measurement of 3 Voltages, 3 Currents) *2)	Three-Phase Four-Wire (3 ϕ 4W)
Voltage	V	V	V_1, V_3	V_1, V_3	V_1, V_2, V_3	V_1, V_2, V_3
	ΣV	—	$\frac{V_1 + V_3}{2}$	$\frac{V_1 + V_3}{2}$	$\frac{V_1 + V_2 + V_3}{3}$	$\frac{V_1 + V_2 + V_3}{3}$
Current	A	A	A_1, A_3	A_1, A_3	A_1, A_2, A_3	A_1, A_2, A_3
	ΣA	—	$\frac{A_1 + A_3}{2}$	$\frac{A_1 + A_3}{2}$	$\frac{A_1 + A_2 + A_3}{3}$	$\frac{A_1 + A_2 + A_3}{3}$
Effective power	W	W	W_1, W_3	W_1, W_3	W_1, W_2, W_3	W_1, W_2, W_3
	ΣW	—	$W_1 + W_3$	$W_1 + W_3$	$W_1 + W_3$	$W_1 + W_2 + W_3$
Reactive power*3)	var	$\sqrt{VA^2 - W^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_3^2 - W_3^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_3^2 - W_3^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_2^2 - W_2^2},$ $\sqrt{VA_3^2 - W_3^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_2^2 - W_2^2},$ $\sqrt{VA_3^2 - W_3^2}$
	$\Sigma \text{ var}$	—	$\sqrt{\Sigma VA^2 - \Sigma W^2}$	$\sqrt{\Sigma VA^2 - \Sigma W^2}$	$\sqrt{\Sigma VA^2 - \Sigma W^2}$	$\sqrt{\Sigma VA^2 - \Sigma W^2}$
Apparent power	VA	$V \times A$	$V_1 \times A_1, V_3 \times A_3$	$V_1 \times A_1, V_3 \times A_3$	$V_1 \times A_1, V_2 \times A_2,$ $V_3 \times A_3$	$V_1 \times A_1, V_2 \times A_3,$ $V_3 \times A_3$
	ΣVA	—	$2 \times \Sigma V \times \Sigma A$	$\sqrt{3} \times \Sigma V \times \Sigma A$	$\sqrt{3} \times \Sigma V \times \Sigma A$	$3 \times \Sigma V \times \Sigma A$
Power factor	PF	$\frac{W}{VA}$	$\frac{W_1}{VA_1}, \frac{W_3}{VA_3}$	$\frac{W_1}{VA_1}, \frac{W_3}{VA_3}$	$\frac{W_1}{VA_1}, \frac{W_2}{VA_2}, \frac{W_3}{VA_3}$	$\frac{W_1}{VA_1}, \frac{W_2}{VA_2}, \frac{W_3}{VA_3}$
	ΣPF	—	$\frac{\Sigma W}{\Sigma VA}$	$\frac{\Sigma W}{\Sigma VA}$	$\frac{\Sigma W}{\Sigma VA}$	$\frac{\Sigma W}{\Sigma VA}$

*1) Wiring selection by pressing switch on 2533E32, 2533E42, 2533E33 or 2533E43.

*2) Wiring settable by changing over switch in 2533E33 or 2533E43.

*3) VA^2 denotes $(VA)^2$.

*Reactive power (var), apparent power (VA) and power factor (PF) of the instrument are obtained by digital computation from voltage, current, effective power, etc.

*When distorted waveshapes are measured, differential in measured values using this instrument and other instrument with different principle of measurement may occur.

(2) When both Voltage and Current Exceed Specified Measurement Ranges

As described in section 2-4-1 (2), connect an external potential transformer (PT) or current transformer (CT) according to Figure 2-10.




Figure 2-10.

<Examples of Calculation When Using PT and CT>

(1) **Measured Voltage** = PT ratio × instrument's voltage reading = $m_1 \cdot V_1$

Example: PT ratio (m_1) 3300/110=30

Instrument's voltage

reading (V_1) 100.00 V

Calculated voltage

($m_1 \cdot V_1$)..... 100 V × 30 = 3 kV

Likewise, the value of $m_3 \cdot V_3$ is calculated.

(2) **Measured Current** = CT ratio × instrument's current reading = $n_1 \cdot A_1$

Example: CT ratio (n_1) 50/5=10

Instrument's current

reading (A_1) 4.000 A

Calculated current

($n_1 \cdot A_1$) 4 A × 10 = 40 A

Likewise, the value of $n_3 \cdot A_3$ is calculated.

(3) **Measured Power** = PT ratio × CT ratio × power reading = $m_1 \cdot n_1 \cdot W_1$

Example: From above, $m_1=30$, $n_1=10$

Instrument's power

reading (W_1) 350.0 W

Therefore, calculated power

($m_1 \cdot n_1 \cdot W_1$) = 105 kW

Likewise, the value of $m_3 \cdot n_3 \cdot W_3$ is calculated.

From the above values, the voltage, current and power of this wiring can be obtained as follows based on the formulas in the column of 3φ3W (2EL) of Table 2-3.

V: $m_1 \cdot V_1$ and $m_3 \cdot V_3$

ΣV : $\frac{m_1 \cdot V_1 + m_3 \cdot V_3}{2}$

A: $n_1 \cdot A_1$ and $n_3 \cdot A_3$

ΣA : $\frac{n_1 \cdot A_1 + n_3 \cdot A_3}{2}$

W: $m_1 \cdot n_1 \cdot W_1$ and $m_3 \cdot n_3 \cdot W_3$

ΣW : $m_1 \cdot n_1 \cdot W_1 + m_3 \cdot n_3 \cdot W_3$

- When it is desired to directly read on the display the values measured as shown above, set the PT and CT transformation ratios by scaling.

Note: The transformation ratios must be the same between two PTs and between two CTs.

For details of scaling, refer to section 2-10 **Setting Scaling (SCALING) Factor**.

2-4-3. Power Measurement of Single-Phase Three-Wire (1 ϕ 3W) System

Three-phase power measuring model uses two input elements. Therefore, by changing DIP switches on the CPU card, single phase three-wire (1 ϕ 3W) power can be measured.

Figure 2-11 shows wiring for the case where the measured voltage and current are within the specified measurement ranges, and Figure 2-12 shows wiring for the case where the measured voltage and current are beyond the specified measurement ranges.

- How to set DIP switches is explained in section 2-12 Setting Internal Switches.

For these wirings, the relationship between measurement items and measured data is shown in the column, single phase three-wire system, in Table 2-3. The calculation method for measured values beyond the specified limits or direct reading of measured value via scaling is similar to section 2-4-2 (2) above.




Figure 2-11.




Figure 2-12.

2-4-4. Power Measurement of Three-Phase Four-Wire (3 ϕ 4W) System

(1) When Both Voltage and Current are Within Specified Measurement Ranges

Referring to section 2-4-2 (1), perform wiring as depicted in Figure 2-13. For this wiring, the relationship between measurement items and measured data is as given in the column, three-phase four-wire system, in Table 2-3.




Figure 2-13.

(2) When Both Voltage and Current are Beyond Specified Measurement Ranges

At this time, external potential transformer (PT) and current transformer (CT) are connected as shown in Figure 2-14.

Measured values of voltage, current and power for this wiring can be calculated based on the column of three-phase four-wire system in Table 2-3 according to the examples of calculation in 2-4-2 (2).

- When it is desired to directly read on the display the values measured as shown above, set the PT and CT transformation ratios by scaling stated in section 2-10. The transformation ratio must be the same among the three PTs and the three CTs.




Figure 2-14.

2-4-5. Power Measurement of Three-Phase Three-Wire ($3\phi 3W$) System

When the three-phase four-wire model, power of three-phase three-wire (measurement of 3 voltages, 3 currents) system can be measured by changing the DIP switches on the CPU card.

Figure 2-15 shows wiring for the case where the measured voltage and current are within the specified measurement ranges, and Figure 2-16 shows wiring for the case where they are beyond the specified ranges.

- Setting of DIP switches is explained in section 2-12 **Setting Internal Switches.**

For these wirings, the relationship between measurement items and measured data is shown in the column, three-phase three-wire (measurement of 3 voltages, 3 currents) system in Table 2-3. Direct reading via scaling of each measured value beyond the specified ranges is similar to section 2-4-2 (2) above.




Figure 2-15.




Figure 2-16.

2-4-6. Correction for Self-Consumed Power

The measured power indicated by the instrument is load power plus power consumed by the input circuit of the instrument connected to the load side.

When it is desired to measure the load power more accurately, the power consumption of the instrument itself must be deducted from the measured value.

(1) When Voltage Terminal is Connected to Load Side

When the source impedance is low and the voltage fluctuation is small, or the load power is relatively small, connect the voltage terminal to the load side. In the wiring diagrams on the instrument's rear panel and this manual, the "voltage terminal is connected to load side".

The loss on the voltage terminal side is almost the same as the instrument's reading when the load is detached. By deducting this value from the value measured when the load is connected, a true load power is obtained.

Since the input resistance of the voltage terminal of the instrument is about $1\text{ M}\Omega$ (constant) over the entire voltage measurement ranges, correction of self-consumed power may hardly be necessary.




Figure 2-17.

(2) When Current Terminal is Connected to Load Side

For power measurement, the current terminal may be connected to the load side besides the wiring stated in (1) above. In this case, by changing the voltage connecting point from P to Q with the load kept connected as shown in Figure 2-18, the power measured by the instrument is the loss on the current terminal side. By deducting this value from the power measured when the voltage connecting point is at P, a true load power is obtained.

The self-consumed power (instrument loss) on the current terminal side is $2\text{ m}\Omega \times \text{current (squared)}$ at 50 Hz. When the instrument loss is sufficiently smaller than the load power, the instrument loss may be ignored.





Figure 2-18.

Related Products**(1) Potential Transformers: 2261, 2262****Class:** 0.2, JIS C 1731**Rated Burden:** 15 VA**Table 2-5.**

Model	Primary	Secondary
226101	220/440/2,200/3,300 V	110 V
226102	15/30/50/75	150 V
226103	100/200/300/500	150 V
226200	3,300/6,600 V	110 V

**(2) Current Transformers: 2241 to 2244****Class:** 0.2**Table 2-6.**

Model	Primary	Secondary
224100	10/15/30/60/100/250/ 300/500/750/1,500 A	5 A
224200	10/15/30/50/100/250/ 300/500/750/1,500 A	5 A
224300	0.5/0.75/1/1.5/2/3/5/ 7.5/10/15/20/30/50/ 75/100 A	5 A
224400	500 A (500 AT)	5 A



2-5. Turning on Power

(1) Setting Status of Keys when Turning on Power

Install the backup batteries according to section 2-2. Before any settings have been made with the front panel keys, the settings of the keys shown in Figure 2-19 when turning on power are at a default status given below. For a DC/AC model, when the power turns on, its DC-CT core is demagnetized.




Figure 2-19.

1) Measurement Mode

A measurement mode is selected by MODE keys shown by ① in Figure 2-19. The initial status of the keys are given in Table 2-7.

Table 2-7.

Key	Initial Setting	Display
☐ WIRING	3 ϕ 3W	Key lamp lit
☐ VOLT	RMS	
☐ FILTER	OFF	Key lamp extinguished
☐ AVG	OFF	
☐ SCALING	OFF	

2) Sampling Mode

The sampling hold status is turned ON or OFF by SAMPLE keys indicated by ② in Figure 2-19. The initial settings are given in Table 2-8.

Table 2-8.

Key	Initial Setting	Display
☐ HOLD	OFF	Key lamp extinguished

At this time, SAMPLE display lamp located near the upper left corner of the front panel flashes at a sampling cycle of about 400 ms. Confirm this.

3) Display Mode

A display mode is selected by FUNCTION and ELEMENT keys corresponding to DISPLAY A, B and C shown by ③ in Figure 2-19. The initial settings of the keys are given in Table 2-9.

Table 2-9.

Corresponding Display	Initial Setting	Display
DISPLAY A	V1	Lamps lit on ☐ V and ☐ 1 keys. Others extinguished.
DISPLAY B	A1	Lamps lit on ☐ A and ☐ 1 keys. Others extinguished.
DISPLAY C	W1	Lamps lit on ☐ W and ☐ 1 keys. Others extinguished.

4) Measurement Range

Each measurement range is selected by VOLTAGE RANGE (V) and CURRENT RANGE (A) keys shown by ④ in Figure 2-19. The initial settings are given in Table 2-10.

Table 2-10.


Measurement Range	Initial Setting	Display
VOLTAGE	600 V	600 lamp lit. Others extinguished.
CURRENT	20 A	20 lamp lit. Others extinguished.

5) Scaling Value

Press  key, shown by ⑤ in Figure 2-19. The key lamp comes on and, at the same time, PT ratio, CT ratio and scaling factor initial set value are indicated on DISPLAY A, B and C, as shown in Table 2-11.

At this time, the most significant digit of DISPLAY A flashes, indicating the value in this place is ready to be changed by setting. It is not due to trouble in the instrument.

Table 2-11.



Display	Initial Scaling Item	Initial Setting and Display
DISPLAY A	PT ratio	
DISPLAY B	CT ratio	
DISPLAY C	SCALING FACTOR	

6) Timer Setting (Only When/INTEG is Added)

Press  key, shown by ⑤ in Figure 2-19. The key lamp comes on, DISPLAY A and B disappear as shown in Table 2-12, and initial timer setting is indicated on DISPLAY C.

At this time,  the most significant digit of DISPLAY C flashes, indicating the value in this place is ready to be changed. It is not due to trouble in the instrument.

Table 2-12.

Display	Initial Setting	Initial Setting and Display
DISPLAY A		
DISPLAY B		
DISPLAY C	Timer (h, min)	

At the same time, INTEGRATOR Keys shown by ⑥ in Figure 2-19 give initial settings shown in Table 2-13.

Table 2-13.

Key	Initial Setting	Display
	OFF	Key lamp extinguished
	ON	Key lamp lit

Note: When the integrator function is not added,  key lamp is also extinguished.

(2) Others

Make sure BATTERY indicator lamp on the upper left corner of the front panel is extinguished.

This lamp is lit when "panel setting information protective dry cells" are not installed or are exhausted.

NOTES

- When setting information is backed up by the batteries, key setting statuses when turning on power are set in last setting when power was turned OFF. When GP-IB or RS-232-C interface is installed, service request mask: IM** and delimiter: DS* (GP-IB interface only) setting at BLOCK output are not protected.
- If power is turned OFF while integrating when an integrator function is added, turning on power again does not resume the integration.

2-6. Setting Voltage and Current Ranges (RANGE)

The voltage and current ranges are set by operating the keys in the shaded area of Figure 2-20. The selected ranges are known by the range indicator lamps located at left of the keys.




Figure 2-20.

Setting is carried out in either automatic range setting mode or fixed range mode.

[AUTO] : Pressing this key selects the automatic range setting mode or fixed range mode alternately.

The automatic range mode is selected when the key lamp is lit. In this mode, a range appropriate for an input signal level is automatically selected.

[V] (**[^]**) : Effective in the fixed range mode (overridden in automatic range setting mode). Each press lowers, (raises) the measurement range down to the minimum or up to the maximum range.

Six ranges each are provided for voltage and current.

Voltage range; 600 V/300 V/150 V/100 V/60 V/30 V

Current range; 20 A/10 A/5 A/2 A/1 A/0.5 A*

*DC/AC meters do not cover 0.5 A range.

[PEAK OVER] : The lamp comes on when the input signal peak level has exceeded 250% of range for voltage or 350% of range for current, indicating the peak value is exceeded.

- A combination of voltage and current ranges determines the power range as follows.

(Power range)=(voltage range)×(current range)

Example: Combination of 100 V range and 5 A range makes a power range of 500 W (at single phase).

- For three-phases, the voltage and current ranges are the same for all the phases.
- In case of an automatic range mode, the range is changed as follows.

(1) The Range Rises When:

At any phase

- The measured value of the measurement range has exceeded 110% of the range (overrange).
- The peak level has exceeded 250% of the range for voltage or 350% for current.

(2) The Range Lowers When:

All the measured values of the range of all phases have dropped to about 30% or less (underrange).

NOTES

- When measuring a wave of a high crestfactor (3.5 min.) at auto range, or when measuring a signal of 5 Hz or less, the range may be indefinite. In such cases, use the fixed range.
- In the auto range mode, the range is changed over as explained in (1) and (2) above. The range may be different for the same input.
- In the auto range mode, the time required for changing the range is:
1 s/step with FILTER ON or
0.2 s/step with FILTER OFF.

2-7. Digital Display (DISPLAY)

The instrument has three digital display sections DISPLAY A, B and C surrounded by  in Figure 2-21, and three parameters or voltage, current and power can be indicated simultaneously.




Figure 2-21.

They display scaling factor setting, hardware configuration when turning ON power and version No.

Their details are as follows.

Display Range:

0.0000 to ± 99999 for DISPLAY A and B
0.0000 to ± 99999 for DISPLAY C

Mode	Max. Display	Display Item
A	± 99999	V, A, W (1, 2, 3, Σ for each)*
B	± 99999	V, A, W (1, 2, 3, Σ for each)* integration lapse (option)
C	± 99999 (± 999999 Wh, Ah)	V, A, W, VA, var, PF, (Hz, Wh, Ah ... option, 1, 2, 3, Σ for each)*

*: 1, 3, Σ for three-phase three-wire

Measured Value

Overrange Indication:

999999

Computed Value

Overflow Indication:

8888888

No Data:

<Measured and Computed Value Display>

By setting the internal switches, the display resolution can be selected between 20000 and 60000 (see section 2-12 Setting Internal Switches). They are factory set at 20000.

This action changes the display resolution and the resolution of A-D converter remains at 20000.

In case of 60000 display, the minimum resolution is greater than 1 digit.

(1) Voltage (V) Display

Dis- play	20000 Display		60000 Display	
	Rating Display	Max. Display	Rating Display	Max. Display
30 V	30.00	42.00	30.000	42.000
60 V	60.00	84.00	60.000	84.000
100 V	100.00	140.00	100.00	140.00
150 V	150.00	210.00	150.00	210.00
300 V	300.0	420.0	300.00	420.00
600 V	600.0	840.0	600.00	840.00

- The input is 10% to 110% of the range but display is available up to 140% of the range (max. display). 0.1% or less of the range gives zero display.

(2) Current (A) Display

Dis- play	20000 Display		60000 Display	
	Rating Display	Max. Display	Rating Display	Max. Display
0.5 A*	0.5000	0.7000	500.00 m	700.00 m
1 A	1.0000	1.4000	1.0000	1.4000
2 A	2.0000	2.8000	2.0000	2.8000
5 A	5.000	7.000	5.0000	7.0000
10 A	10.000	14.000	10.000	14.000
20 A	20.000	28.000	20.000	28.000

*DC/AC meters do not cover 0.5 A range.

- The input is 10% to 110% of the range but display is available up to 140% of the range (max. display). 0.1% or less of the range gives zero display.

(3) Effective Power (W), Reactive Power (var) and Apparent Power (VA) Display

Combinations of voltage and current ranges make the following rating ranges.

20000 Display Resolution

Voltage Range \ Current Range	0.5 A*	1 A	2 A	5 A	10 A	20 A
30 V	15.000	30.00	60.00	150.00	300.0	600.0
60 V	30.00	60.00	120.00	300.0	600.0	1200.0
100 V	50.00	100.00	200.00	500.0	1000.0	2000.0
150 V	75.00	150.00	300.0	750.0	1500.0	3.000k
300 V	150.00	300.0	600.0	1500.0	3.000k	6.000k
600 V	300.0	600.0	1200.0	3.000k	6.000k	12.000k

*DC/AC meters do not cover 0.5 A range.

60000 Display Resolution

Voltage Range \ Current Range	0.5 A*	1 A	2 A	5 A	10 A	20 A
30 V	15.000	30.000	60.00	150.00	300.0	600.00
60 V	30.000	60.000	120.00	300.0	600.0	1200.0
100 V	50.00	100.00	200.00	500.00	1000.0	2000.0
150 V	75.00	150.00	300.0	750.0	1500.0	3000.0
300 V	150.00	300.0	600.0	1500.0	3000.0	6000.0
600 V	300.0	600.0	1200.0	3000.0	6000.0	12.000k

*DC/AC meters do not cover 0.5 A range.

2533E32 and 2533E42... $300.0 \times 2 = 600.0$ (20000 display resolution)

$300.00 \times 2 = 600.00$ (60000 display resolution)

2533E33 and 2533E43... $300.0 \times 3 = 900.0$ (20000 display resolution)

$300.00 \times 3 = 900.0$ (60000 display resolution)

- Overrange occurs when 140% of the rated range is exceeded and **999999** is displayed.

(4) Power Factor (PF) Display

Display Range: 0.000 to ± 1.000

When the measured value of W or VA is beyond the measurement extent (10% or less, 110% or more of F.S.), the computed power factor may exceed 1. Therefore, the following processing is carried out.

- **1.000** is displayed when the computed power factor is 1.000 to 2.000 or **888888** is displayed when over 2.000.

Display of Scaling Factor

Display Range: 0.0001 to 10000

- Values of 0.0000 and 10001 or less cannot be input. In this case, the display flashes, indicating that input is unavailable.
- By MODE's SCALING Key **[SCALING]**, the measured value can be multiplied by a scaling factor for display.

If a set combination is such that the display value of 100% of rating exceeds **99999M** by setting a scaling factor, measured and computed data are not displayed but "**(8) 888888**" is displayed.

2-8. Selecting Digital Display (DISPLAY)

Measured and computed values to be indicated on the digital display sections DISPLAY A, DISPLAY B and DISPLAY C are selected by combinations of FUNCTION keys and ELEMENT keys in the shaded area of Figure 2-22.




Figure 2-22.

<FUNCTION keys>

- V** : for display of voltage.
By **VOLT** key of measurement mode (MODE), rms value measurement and rms value display, and mean value rectified rms value calibration display can be selected.
- A** : for display of current.
Rms current intensity is displayed.
- W** : for display of effective power.

Above keys are common to DISPLAY A, DISPLAY B and DISPLAY C.

- INTEG TIME** : effective for model provided with an integrating function (option) and applies to DISPLAY B only.
(IM 2533E-50E).
This key is overridden for a model which has no integrating function.

The following keys apply to DISPLAY C only.

- var** : for display of reactive power.
Reactive power var is calculated by:
$$\sqrt{(\text{apparent power VA})^2 - (\text{effective power W})^2}$$
- VA** : for display of apparent power.
Apparent power VA is computed by $V \times A$.

- PF** : for display of power factor (Power Factor).
The power factor is computed by effective power W ÷ apparent power VA.
- Hz** : effective for a model provided with a frequency measuring function (option).
(IM 2533E-50E).
- Wh** and **Ah** keys are effective for a model provided with an integrating function (option)
(IM 2533E-50E).

The keys are overridden for a model not provided with the above optional function.

<ELEMENT Keys>

- 1** : selects V, A, W, etc. measured by input module 1.
- 2** : selects V, A, W, etc. measured by input module 2.
(Not effective for three-phase three-wire model 2533 12 or 2533 22.)
- 3** : selects V, A, W, etc. measured by input module 3.
- Σ** : used to obtain a sum of V1 to V3 or A1 to A3 for voltage or current, or W1 to W3 for power.
For computation, refer to Table 2-15.

- Display mode settable on DISPLAY A
 $V_1, (V_2), V_3, \Sigma V$
 $A_1, (A_2), A_3, \Sigma A$
 $W_1, (W_2), W_3, \Sigma W$
- Display mode settable on DISPLAY B
 $V_1, (V_2), V_3, \Sigma V$
 $A_1, (A_2), A_3, \Sigma A$
 $W_1, (W_2), W_3, \Sigma W$
 INTEG TIME (effective only for models equipped with the optional integrating function)
- Display mode settable on DISPLAY C
 $V_1, (V_2), V_3, \Sigma V$
 $A_1, (A_2), A_3, \Sigma A$
 $W_1, (W_2), W_3, \Sigma W$
 $var_1, (var_2), var_3, \Sigma var$
 $VA_1, (VA_2), VA_3, \Sigma VA$
 $PF_1, (PF_2), PF_3, \Sigma PF$
 $Hz (V_1), Hz (A_1)$
 (effective only for models equipped with the optional frequency measuring function)
 $Wh_1, (Wh_2), Wh_3, \Sigma Wh$
 $Ah, (Ah_2), Ah_3, \Sigma Ah$
 (effective only for models equipped with the optional integrating function)
- Some displays are impossible depending on combinations of FUNCTION and ELEMENT of DISPLAY A, B and C. In such a case, the lamp for FUNCTION or ELEMENT selected last flashes. At this time, the measurement is pursued in a mode standing before selecting FUNCTION.

When DISPLAY C selects VA, var or PF to be obtained by software computation, the following conditions must be satisfied.

Table 2-14.

Display C	Display A/Display B
VA_i	Either V_i or A_i is selected
Σ	Either ΣV or ΣA is selected
var_i, PF_i	2 different combinations of V_i, A_i and W_i
$\Sigma Var, \Sigma PF$	2 different combinations of $\Sigma V, \Sigma A$ and ΣW

i denotes ELEMENT (1 to 3) of the same number.

Table 2-15.

Wiring Indicated Item		Single-Phase Two-Wire (1 ϕ 2W)	Single-Phase Three-Wire (1 ϕ 3W) *1)	Three-Phase Three-Wire (Measurement of 2 Voltages, 2 Currents, 3 ϕ 3W)	Three-Phase Three-Wire (Measurement of 3 Voltages, 3 Currents) *2)	Three-Phase Four-Wire (3 ϕ 4W)
Voltage	V	V	V_1, V_3	V_1, V_3	V_1, V_2, V_3	V_1, V_2, V_3
	ΣV	—	$\frac{V_1 + V_3}{2}$	$\frac{V_1 + V_3}{2}$	$\frac{V_1 + V_2 + V_3}{3}$	$\frac{V_1 + V_2 + V_3}{3}$
Current	A	A	A_1, A_3	A_1, A_3	A_1, A_2, A_3	A_1, A_2, A_3
	ΣA	—	$\frac{A_1 + A_3}{2}$	$\frac{A_1 + A_3}{2}$	$\frac{A_1 + A_2 + A_3}{3}$	$\frac{A_1 + A_2 + A_3}{3}$
Effective power	W	W	W_1, W_3	W_1, W_3	W_1, W_2, W_3	W_1, W_2, W_3
	ΣW	—	$W_1 + W_3$	$W_1 + W_3$	$W_1 + W_3$	$W_1 + W_2 + W_3$
Reactive power *3)	var	$\sqrt{VA^2 - W^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_3^2 - W_3^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_3^2 - W_3^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_2^2 - W_2^2},$ $\sqrt{VA_3^2 - W_3^2}$	$\sqrt{VA_1^2 - W_1^2},$ $\sqrt{VA_2^2 - W_2^2},$ $\sqrt{VA_3^2 - W_3^2}$
	$\Sigma \text{ var}$	—	$\sqrt{\Sigma VA^2 - \Sigma W^2}$	$\sqrt{\Sigma VA^2 - \Sigma W^2}$	$\sqrt{\Sigma VA^2 - \Sigma W^2}$	$\sqrt{\Sigma VA^2 - \Sigma W^2}$
Apparent power	VA	$V \times A$	$V_1 \times A_1, V_3 \times A_3$	$V_1 \times A_1, V_3 \times A_3$	$V_1 \times A_1, V_2 \times A_2,$ $V_3 \times A_3$	$V_1 \times A_1, V_2 \times A_3,$ $V_3 \times A_3$
	ΣVA	—	$2 \times \Sigma V \times \Sigma A$	$\sqrt{3} \times \Sigma V \times \Sigma A$	$\sqrt{3} \times \Sigma V \times \Sigma A$	$3 \times \Sigma V \times \Sigma A$
Power factor	PF	$\frac{W}{VA}$	$\frac{W_1}{VA_1}, \frac{W_3}{VA_3}$	$\frac{W_1}{VA_1}, \frac{W_3}{VA_3}$	$\frac{W_1}{VA_1}, \frac{W_2}{VA_2}, \frac{W_3}{VA_3}$	$\frac{W_1}{VA_1}, \frac{W_2}{VA_2}, \frac{W_3}{VA_3}$
	$\Sigma \text{ PF}$	—	$\frac{\Sigma W}{\Sigma VA}$	$\frac{\Sigma W}{\Sigma VA}$	$\frac{\Sigma W}{\Sigma VA}$	$\frac{\Sigma W}{\Sigma VA}$

*1) Wiring selection by pressing switch on 2533E32, 2533E33, 2533E42 or 2533E43.

*2) Wiring settable by changing over switch in 2533E33 or 2533E43.

*3) VA^2 denotes $(VA)^2$.

*Reactive power (var), apparent power (VA) and power factor (PF) of the instrument are obtained by digital computation from voltage, current, effective power, etc.

*When distorted waveshapes are measured, differential in measured values using this instrument and other instrument with different principle of measurement may occur.






Single-Phase (Two-Wire) System**Single-Phase (Three-Wire) System****Three-Phase Three-Wire System (Measurement of 2 Voltages, 2 Currents)****Three-Phase Three-Wire System (Measurement of 3 Voltages, 3 Currents)****Three-Phase Four-Wire System**

Figure 2-23.

2-9. Selecting Measurement Mode (MODE)

Operation of keys in the shaded area of Figure 2-24 selects a response time and determines whether to perform averaging or scaling.




Figure 2-24.

WIRING : effective for three-phase four-wire models 2533E13 and 2533E23.
 ☆ 3φ3W
 ● 3φ4W

Press the key to select three-phase three-wire or three-phase four-wire to match the wiring system.

Three-phase three-wire wiring is selected when the lamp is lit. On three-phase three-wire models 2533E32 and 2533E42, the lamps remain lit, and the keys are invalid. With the three-phase three-wire setting (lamp lit), three different wiring modes can be selected by setting the internal switches (page 2-33).

● Three-phase three-wire (measurement of 2 voltages/2 currents) mode... factory set

● Three-phase three-wire (measurement of 3 voltages/3 currents) mode

● Single-phase three-wire mode

VOLT : rms value measurement/rms value display (RMS) or mean value rectification/rms value calibration display (MEAN) is selected.
 ☆ RMS
 ● MEAN

RMS mode is selected when the lamp is lit, or MEAN mode is selected when the lamp is extinguished.

FILTER : the response for analog computation results of voltage, current and power is changed over.

When the lamp is lit (FILTER ON), the response is 2 seconds (when changing from 30% to 100% of range). When the lamp is extinguished (FILTER OFF), the response is 400 ms. When FILTER is ON, the display is stabilized in case the measured value is fluctuating at 2 to 10 Hz.

AVG : When voltage, current and effective power are measured, whether to display after exponential averaging or not is determined. When the lamp is lit, averaging is ON or, when extinguished, averaging is OFF.

*: Exponential averaging is carried out by the expression:

$$A_n = A_{n-1} + \frac{1}{K}(M_n - A_{n-1})$$

Where A : exponential averaging data

A_{n-1} : preceding exponential averaging data

M_n : measured data

K : attenuation factor. $K=8$ on this instrument.

When **AVG** key is turned ON, measured data are displayed for the first time, and their value constitutes the preceding exponential averaging data A_{n-1} in the second computation.

SCALING : determines whether to multiply the measured value by a scaling factor (SCALING ON) or not (SCALING OFF).

When the lamp is lit, SCALING is ON or, when extinguished, SCALING is OFF.

SCALING ON, the unit display changes accordingly.


HOLD : selects free run (FREE RUN: 400 ms) or hold sampling (display cycle). When the key lamp is lit, sample hold mode is selected and SAMPLE display lamp is extinguished. When that key lamp is extinguished, a free run mode is selected and SAMPLE display lamp flashes at 400 ms cycle.

TRIG : effective in sample hold mode.

Pressing **TRIG** key actuates a measurement once and updates the display. At this time, SAMPLE display lamp flashes once.

■ Timing chart

FREE RUN (sample hold OFF)



- With an internal interrupt signal of 400 ms cycle, A-D converter is activated for computation and display and data is sent to GP-IB interface.
- Pressing **TRIG** key or inputting a signal to the EXT A-D START, activates the A-D converter once for computation and display and sends data to GP-IB interface. At this time, SRQ of A-D END is generated.
- Computation and display are performed with an internal interrupt signal of 400 ms even without pressing **TRIG** key or inputting a signal to EXT A-D START. Therefore, when the display mode (FUNCTION, ELEMENT) is changed in sample hold mode, data which is ready to be displayed is displayed. If display is impossible, - - - - - is indicated, indicating an absence of data.

2-10. Setting Scaling (SCALING) Factor

Measured voltage, current and power multiplied by a scaling factor can be displayed. When measuring an input beyond the measurement range, an external potential transformer (PT) or current transformer (CT) is used. This function provides a direct reading in terms of the primary side value. Power scaling (SCALING FACTOR) can be converted to calorie (CAL) or other physical quantities conveniently. When scaling, parameter setting keys in the shaded area of Figure 2-25 are used.




Figure 2-25.

Given K_v is the scaling factor of voltage (PT RATIO), K_i is the scaling factor of current (CT RATIO), and K_w is the scaling factor of power (SCALING FACTOR), the displayed value of each function is as follows.

	<Measured data>	<Scaling data>
Voltage	V	$K_v \times V$
Current	A	$K_i \times A$
Effective power	W	$K_v \times K_i \times K_w \times W$
Reactive power	var	$K_v \times K_i \times K_w \times \text{var}$
Apparent power	VA	$K_v \times K_i \times K_w \times \text{VA}$

- Scaling factor setting range 0.0001 to 10000.
- By **SCALING** key of MODE, the digital display can be changed over to scaling ON/OFF.
- When the power scaling factor K_w is other than 1.0000, turning ON scaling of digital display clears the units of W, VA and var and lights up ► mark on display C.

At this time, k, m and M are indicated as they are. If, by setting a scaling factor, the displayed value of 100% of rating exceeds 99999M, measured data are not displayed but "8888888" is indicated.

- Measured and computed data can be displayed so long as the measured data do not exceed 140% of rating. In case of computation of VA consisting of two measured values, for example, up to 196% of rating can be displayed as a computed value.

Function of Scaling Factor Setting Keys


SCALING : pressing the key selects a scaling factor setting mode.

At this time, the key lamp comes on and, on DISPLAY A, B and C, PT ratio, CT ratio and SCALING FACTOR are displayed, respectively. The initial value is 1.0000. All units disappear and the lamps of PT RATIO, CT RATIO and SCALING FACTOR come on. The most significant digit on DISPLAY A flashes.

> : moves the digit which flashes indicating it is changeable. Every time it is pressed, the changeable digit is moved in the sequence given below. Holding it down can move it automatically in the same sequence.



 : changes a value. Every time this key is pressed, the displayed value can be changed in the following sequence. Holding down the key permits change in the same sequence.



 : moves the decimal point position. Every time the key is pressed, the decimal point position is moved in the following sequence. Holding it down moves the position in the same way.



 : enters a scaling factor. Pressing the key performs an entry.

- When the scaling factor is within the specified range (0.0001 to 10000), the control transfers to the next display (DISPLAY B or DISPLAY C).

Pressing  key for DISPLAY C terminates scaling factor setting, and the measured and computed value display mode resumes.

- By pressing  key when the specified range is exceeded, all digits of the relevant display flash. Pressing any of ,  and  keys at this time can recall the display where an error has occurred. Pressing  key again can set the scaling factor of the DISPLAY A to start with. Pressing FUNCTION and ELEMENT keys resumes an ordinary measurement and computation display mode from scaling factor setting mode.

Setting Examples


Let us carry out a measurement using a potential transformer (PT) of 3,300 V (primary)/110 V (secondary) and a current transformer (CT) of 100 A (primary)/5 A (secondary) and set a scaling factor for direct digital reading.

First obtain PT and CT ratios.


PT ratio: 3,300 V / 110 V = 30

CT ratio: 100 A / 5 A = 20

- (1) Press  key in SET PARAMETER to select a scaling factor setting mode.




- (2) ,  : set the flashing digit to 3.



- (3)  : move the decimal point and enter the PT ratio 30.000



- (4)  : enter the PT ratio. At this time the most significant digit of DISPLAY B flashes.



- (5) , ,  : in the same way, set the CT ratio to 20.000 and enter.



- (6)  : in the example shown, the power scaling factor need not be set. Just press the ENTRY key to resume the measured and computed value display mode. Thus the scaling factor has been set.
- (7) In sample hold mode, press  key, and make sure the scaling ON value is 30 times ± 1 digit for voltage, 20 times ± 1 digit for current, and 600 times ± 1 digit for power, with respect to the SCALING OFF value.

2-11. How to Use Connector

The following is available by REMOTE CONTROL & ANALOG OUTPUT connector depicted in Figure 2-26.

- 1) A-D converter start by external signal
 - 2) Observation of input voltage and current waveform
 - 3) Taking out of analog outputs proportional to voltage and current rms values and effective power.
- Tables 2-17 and 2-18 show pin numbers of analog outputs and signal names.




Figure 2-26.

- The analog output is 5 V DC for the following rated input.

Table 2-16.

V ₁ , V ₂ , V ₃ , Σ V		Product of selected V and A ranges
A ₁ , A ₂ , A ₃ , Σ A		
W ₁ , W ₂ , W ₃		Product of selected V and A ranges Example: 100 V and 5 A → 500 W
Σ W	1ϕ3W 3ϕ3W	W ₁ to W ₃ × 2
	3ϕ4W	W ₁ to W ₃ × 3

Three-Phase Three-Wire Models 2533E32 and 2533E42

Table 2-17.

Pin No.	Signal Name	
1	DIG.COM	
2	DIG.COM	
3	BUSY	
4		
5		
6		
7		
8		
9		
10	ANALOG COM	
11	A1 (rms)	
12		
13		
14		
15	ANALOG COM	
16	A1	Input wave output
17		
18	A3	
19	+5V	
20		
21	EXT A-D START	
22	ANALOG COM	
23		
24	W1	
25		
26		
27		
28	ANALOG COM	
29	V1 (rms or mean)	
30		
31	V3(rms or mean)	
32	ΣV (rms or mean)	
33	ANALOG COM	
34	V1	Input wave output
35		
36	V3	

Three-Phase Four-Wire Models 2533E33 and 2533E43

Table 2-18.

Pin No.	Signal Name	
1	DIG.COM	
2	DIG.COM	
3	BUSY	
4		
5		
6		
7		
8		
9		
10	ANALOG COM	
11	A1 (rms)	
12	A2 (rms)	
13	A3 (rms)	
14	ΣA (rms)	
15	ANALOG COM	
16	A1	Input wave output
17	A2	
18	A3	
19	+5V	
20		
21	EXT A-D START	
22		
23	ANALOG COM	
24	W1	
25	W2	
26	W3	
27	ΣV (rms)	
28	ANALOG COM	
29	V1 (rms or mean)	
30	V2 (rms or mean)	
31	V3 (rms or mean)	
32	ΣV (rms or mean)	
33	ANALOG COM	
34	V1	Input wave output
35	V2	
36	V3	

- The input wave output is an AC waveform of approximately 1 V rms at rated input. The maximum load current is 0.1 mA, the maximum load capacitance is 100 pF, and the output resistance is 20 Ω .
- Each analog output V (rms), A (rms), W is 5 V DC at rated input with maximum load current of 0.1 mA and maximum load capacitance of 1000 pF.

(1) EXT A-D START and BUSY Signal

In sample hold mode, the A-D converter can be started and synchronized with an external signal. It is also effective in remote mode with GP-IB interface.

To start with an external signal, the pulse width must be 20 ms or more, and the sampling interval must be 400 ms or more.




Figure 2-27.




Figure 2-28. EXT A-D START




Figure 2-29. A-D BUSY

(2) Input Wave Output

Input wave isolated from voltage and current input signal can be observed.




Figure 2-30. Voltage (V) Input Monitor Circuit




Figure 2-31. Current (A) Input Monitor Circuit

(3) Analog Output

DC voltages proportional to measured voltage, current and effective power are output simultaneously.

2533E32 and 2533E42 output a total of nine analog signals: 3 voltages (V1, V3, ΣV), 3 currents (A1, A3, ΣA) and 3 effective powers (W1, W3, ΣW).

2533E33 and 2533E43 can deliver up to a total of 12 outputs: 4 voltages (V1, V2, V3, ΣV), 4 currents (A1, A2, A3, ΣA) and 4 effective powers (W1, W2, W3, ΣW).

When the analog outputs are combined with a multipen recorder, measured values can be continuously recorded, or the instrument can be used as a transducer.




Figure 2-32 V, A and W Output Circuit




Figure 2-33. Analog Output Response

2-12. Setting Internal Switches

The display resolution can be changed and the wiring system can be designated by setting DIP switches in 2533E.

Switch Setting Procedure Cord

- (1) Disconnect the Power Cable from 2533E.

Remove the rubber cover located on the right or left side of the 2533E. If a rackmount adapter is installed, remove it with a screwdriver.

- (2) With a screwdriver, loosen four screws from the upper case.

- (3) Remove the upper case.




Figure 2-34.

- (4) Referring to Figure 2-35, set the DIP switches as desired. Do not tamper with other parts to avoid a malfunction.

Do not drop foreign matter into the mainframe.




Figure 2-35.

- All the switches are factory set at OFF.
Display resolution: 20000
Wiring system: Triple phase 3-wire (measurement of
2 voltages, 2 currents)

- (5) After the setting the switches, replace the upper case, tighten the screws, and mount the rubber cover or rack mount adapter. The internal switches have now been set.

3. MAINTENANCE

3-1. Storage

When storing the instrument, avoid the following locations.

- Place containing excessive humidity
- Place exposed to direct sunshine or where temperature is high
- Near heat source
- Place subjected to excessive vibration
- Place filled with dust, corrosive gases or salty air

If the operation is abnormal and repair is necessary, contact the sales representative.

When the repair is billable, contact the service center given on the back cover.

3-2. Replacing Fuse

- (1) If the power fuse has blown, replace it with a furnished fuse: 1 A time lag type (parts number: A9050KF) for 100 V series or 0.5 A time lag type (parts number: A9049KF) for 200 V series.
- (2) When replacing the fuse, disengage the power cord from the rear panel and turn the fuse holder counterclockwise.

CAUTION

When replacing the fuse, turn off the power switch and disconnect the power cord from the power connector on the 2533E.

4. REFERENCES

4-1. Error Code and Hardware Configuration Lists

Given below are a list for error codes displayed by self-test when turning ON power or output by GP-IB interface, and a corresponding list between hardware configuration and codes displayed when turning ON power.

1. Error Code List

Error Code	Description	Operation of 2533E
Self-test and Initial Setting when Turning ON Power		
001	RAM (U4) is faulty	<i>Err 001</i> is indicated on DISPLAY C and hold mode is set
002	ROM (U2) is faulty	<i>Err 002</i> is indicated on DISPLAY C and hold mode is set
003	ROM (U3) is faulty	<i>Err 003</i> is indicated on DISPLAY C and hold mode is set
004	Board combination error (A-D converter board is absent or input section board combination is erroneous)	<i>Err 004</i> is indicated on DISPLAY C and hold mode is test
005	Internal switch setting error (1, 2 set at ON)	<i>Err 005</i> is indicated on DISPLAY C and hold mode is test
006	On three-phase three-wire model 2533E 32 or 2533E42, internal switches are set to measurement of 3 voltages, 3 currents	<i>Err 006</i> is indicated on DISPLAY C and hold mode is test
Related to GP-IB		
100	Command error (undefined command is received)	• Service request SRQ is generated (syntax error) • "ERR 100 C_R L_F" is sent when OE command is received
101	Parameter (• Parameter is beyond specified range • DISPLAY and mode combination error)	• Service request SRQ is generated (syntax error) • "ERR 101 C_R L_F" is sent when OE command is received • Lamp of designated function flashed for combination errors
107	• While message (setting information, error code) is being output, A-D conversion is started from GP-IB controller in sample HOLD mode • A-D conversion is started by "ST", "TRG" while not in HOLD mode	• Service request SRQ is generated (syntax error) • "ERR 107 C_R L_F" is sent when OE command is received

Error Code	Description	Operation of 2533E
Processing error		
103	Result of scaling factor computation overflows display digits	● “(8)888888” is indicated on relevant display ● Service request SRQ is generated (OVER) ● “ERR 103 C_R L_F” is sent when OE command is received
104	Measured data overflow (input of A-D converter exceeds 140% of range rating)	● “99999” is indicated on relevant display ● Service request SRQ is generated (OVER) ● “ERR 104 C_R L_F” is sent when OE command is received
105	Measured data is absent	● “(-) - - - - - ” is indicated on relevant display ● Service request SRQ is generated (OVER) ● “ERR 105 C_R L_F” is sent when OE command is received
106	Voltage peak value overflow (voltage peak value exceeds 250% of range rating)	● Voltage PEAK OVER lamp comes on ● Service request SRQ is generated (OVER) ● “ERR 106 C_R L_F” is sent when OE command is received
108	Current peak value overflow (current peak value exceeds 350% of range rating)	● Current PEAK OVER lamp comes on ● Service request SRQ is generated (OVER) ● “ERR 108 C_R L_F” is sent when OE command is received
Hardware error		
200	A-D converter error	Err 200 is indicated on DISPLAY C
Data setting error		
	Scaling factor set value is beyond setting range (0.0001 to 10000)	Entire set value flashes as 

2. Hardware Configuration and Error Codes

Model	Interface	INTEG	FRQ	Code No.
AC Model (Three-phase Four-wire)	RS-232-C	○	○	TYPE01
		○	×	TYPE03
		×	○	TYPE05
		×	×	TYPE07
	GP-IB	○	○	TYPE08
		○	×	TYPE10
		×	○	TYPE12
		×	×	TYPE14
AC Model (Three-phase Three-wire)	RS-232-C	○	○	TYPE33
		○	×	TYPE35
		×	○	TYPE37
		×	×	TYPE39
	GP-IB	○	○	TYPE40
		○	×	TYPE42
		×	○	TYPE44
		×	×	TYPE46
DC/AC Model (Three-phase Four-wire)	RS-232-C	○	○	TYPE17
		○	×	TYPE19
		×	○	TYPE21
		×	×	TYPE23
	GP-IB	○	○	TYPE24
		○	×	TYPE26
		×	○	TYPE28
		×	×	TYPE30
	—	○	○	TYPE25
		○	×	TYPE27
		×	○	TYPE29
		×	×	TYPE31
DC/AC Model (Three-phase Three-wire)	RS-232-C	○	○	TYPE49
		○	×	TYPE51
		×	○	TYPE53
		×	×	TYPE55
	GP-IB	○	○	TYPE56
		○	×	TYPE58
		×	○	TYPE60
		×	×	TYPE62

- Optional function provided (○), not provided (×).

5. SCHEMATIC DIAGRAMS AND ELECTRONIC PARTS LIST

Par.	Description	Ass'y No.	Fig. No.	Page
1	Models 2533E32 and 2533E33 Digital Power Meter Overall Wiring	————	5-1a	5-3
	Models 2533E42 and 2533E43 Digital Power Meter Overall Wiring	————	5-1b	5-4
2	AC Input Board Ass'y (for Models 2533E32 and 2533E33) Schematic Diagram	B9278JA	5-2a	5-5
	AC Input Board Ass'y (for Models 2533E32 and 2533E33) Components Location Diagram		5-2b	5-6
	AC Input Board Ass'y (for Models 2533E32 and 2533E33) Electronic Parts List		——	5-6
3	Sub Board Ass'y (for Models 2533E42 and 2533E43) Schematic Diagram	B9278JE	5-3a	5-8
	Sub Board Ass'y (for Models 2533E42 and 2533E43) Components Location Diagram		5-3b	5-9
	Sub Board Ass'y (for Models 2533E42 and 2533E43) Electronic Parts List		——	5-9
4	DC Input Board Ass'y (for Models 2533E42 and 2533E43) Schematic Diagram (1/2)	B9278JF	5-4a	5-10
	DC Input Board Ass'y (for Models 2533E42 and 2533E43) Schematic Diagram (2/2)		5-4b	5-11
	DC Input Board Ass'y (for Models 2533E42 and 2533E43) Components Location Diagram		5-4c	5-12
	DC Input Board Ass'y (for Models 2533E42 and 2533E43) Electronic Parts List		——	5-13
5	RMS Board Ass'y Schematic Diagram	B9278JB	5-5a	5-16
	RMS Board Ass'y Components Location Diagram		5-5b	5-17
	RMS Board Ass'y Electronic Parts List		——	5-18
6	SUM MPX Board Ass'y Schematic Diagram	B9278JC	5-6a	5-20
	SUM MPX Board Ass'y Components Location Diagram		5-6b	5-21
	SUM MPX Board Ass'y Electronic Parts List		——	5-22
7	A/D Converter Board Ass'y Schematic Diagram	B9278JD	5-7a	5-23
	A/D Converter Board Ass'y Components Location Diagram		5-7b	5-24
	A/D Converter Board Ass'y Electronic Parts List		——	5-25
8	Display Control Board Ass'y Schematic Diagram	B9278JH	5-8a	5-27
	Display Control Board Ass'y Components Location Diagram		5-8b	5-28
	Display Control Board Ass'y Electronic Parts List		——	5-29
9	CPU Board Ass'y Schematic Diagram (1/2)	B9278JJ	5-9a	5-30
	CPU Board Ass'y Schematic Diagram (2/2)		5-9b	5-31
	CPU Board Ass'y Components Location Diagram		5-9c	5-32
	CPU Board Ass'y Electronic Parts List		——	5-33
10	Display Board Ass'y Schematic Diagram	B9278JK	5-10a	5-34
	Display Board Ass'y Components Location Diagram		5-10b	5-35
	Display Board Ass'y Electronic Parts List		——	5-36
11	Mother Board Ass'y Schematic Diagram (1/2)	B9278JL	5-11a	5-37
	Mother Board Ass'y Schematic Diagram (2/2)		5-11b	5-38
	Mother Board Ass'y Components Location Diagram		5-11c	5-39
	Mother Board Ass'y Electronic Parts List		——	5-40
12	Power Supply Board Ass'y (for Models 2533E32 and 2533E33) Schematic Diagram	B9278JM	5-12a	5-41
	Power Supply Board Ass'y (for Models 2533E32 and 2533E33) Components Location Diagram		5-12b	5-42
	Power Supply Board Ass'y (for Models 2533E32 and 2533E33) Electronic Parts List		——	5-42
13	Power Supply Board Ass'y (for Models 2533E42 and 2533E43) Schematic Diagram	B9278JN	5-13a	5-43
	Power Supply Board Ass'y (for Models 2533E42 and 2533E43) Components Location Diagram		5-13b	5-44
	Power Supply Board Ass'y (for Models 2533E42 and 2533E43) Electronic Parts List		——	5-44

Note: Unless otherwise specified, board assemblies are common to the Model 2533E32, 2533E33, 2533E42 and 2533E43.

IM 2533E-03E

INDEX

List of abbreviations


AC	alternating current	IC	integrated circuit	RTD	resistance temperature
ADPTR	adapter	IND	inductance, induction	RTRY	detector
AL	aluminum	ISLN	isolation		rotary
AMP	amplifier	ISOL	isolator	SEG	segment
ASSY	assembly	JIS	Japanese industrial	SHLD	shielded
BAT	battery		standard	Si	silicon
BFR	buffer	JUMP	jumper	SKT	socket
BUZ	buzzer	L	inductor	SNSR	sensor
CAP	capacitor	LCD	liquid crystal display	SPLY	supply
CAR	carbon	LED	light-emitting diode	STAB	stabilizer
CBL	cable	LSI	large-scale integrated circuit	STD	standard
CCT	circuit			STEPG	stepping
CER	ceramic	MDL	module	SVO	servo
CHP	chopper	MET	metal (lized)	SW	switch
CNTR	counter	MOD	modulator	SYN	synchronous
COAX	coaxial	NOM VAL	nominal value	Ta	tantalum
COM	common	OPT	optical	TC	thermocouple
COMP	composition	OSC	oscillator	TEMP	temperature
CONN	connector	PB	printed board	TERM	terminal
CONV	converter	PBA	printed board assembly	TGL	toggle
CT	current transformer	PEC	photoelectric cell	THERMO	thermostat
DC	direct current	POLYE	polyester	THMS	thermistor
DET	detector	POLYS	polystyrene	UJT	unijunction transistor
DSPL	display	POT	potentiometer	VAR	variable
ELECT	electrolytic	PT	potential transformer	WW	wire wound
EXT	external, extension	PWR	power	XDRC	transducer
FET	field effect transistor	RAM	random access memory	XFMR	transformer
FLEX	flexible	RBN	ribbon	XSTR	transistor
FLM	film	RECP	receptacle	XTAL	crystal
FLTR	filter	RECT	rectifier	ZNR	zener
FXD	fixed	RES	resistor		
Ge	germanium	RGLTR	regulator		
GEN	generator	ROM	read only memory		
GND	ground				

Example

CONN : multi = multi connector
CAP : fxd Al elect = Fixed aluminum electrolytic capacitor
CAP : fxd polye flm = Fixed polyester film capacitor
RES : fxd car flm = Fixed carbon film resistor
RES : var ww = Wirewound variable resistor
SW : rtry = rotary switch

NOTES

1. Components — especially ICs — which are equivalent to components shown in the schematic diagrams and parts list, but manufactured by other manufacturers, can in general be used in the instrument.
2. Subject to change without notice; changes may be made to improve the instrument's performance.



(July 1992)

Note: Parenthesized value is for the instrument of 200 V system.

Figure 5-1a. Models 2533E32 and 2533E33 Digital Power Meter Overall Wiring.





Figure 5-1b. Models 2533E42 and 2533E43 Digital Power Meter Overall Wiring.

Note: Parenthesized value is for the instrument of 200 V system.



(July 1992)

Figure 5-2a. AC Input Board Ass'y (for Models 2533E32 and 2533E33): B9278JA Schematic Diagram.

5-2. AC Input Board Ass'y (for Models 2533E32 and 2533E33): B9278JA. (continued)

Item	Part No.	Part Name and Description					Remarks
R76	A1102RM	Res: fxd met flm	360Ω	±1%	¼W	LF¼ 360ΩF	4 elements not assigned
R77	A9029RL	Res: module	10kΩ	±5%	1/8 W	RK1/8 B4 10kΩJ	
R78~R80							
R81	A9182RL	Res: module				MRP1486	
C1	A9229CY	Cap: fxd polye flm	0.1μF	±10%	100V	ECQ-E 1104KZ	4 elements
C2	A9250CY	Cap: fxd polye flm	0.01μF	±10%	50V	MFL5002-103K	
C3	A9068CN	Cap: fxd mica	470pF	±10%	100V	DM15C 471K1	
C4	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K	
C5, C6	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C7, C8	A9360CA	Cap: fxd Al elect	47μF		35V	ECEA1VS470R	
C9, C10	A9106CT	Cap: fxd Ta elect	22μF	±20%	35V	221M3502-226M5	
C11	A1262CM	Cap: fxd mica	47pF	±10%	100V	DM15C 221K1	
C12	A9009CL	Cap: module	1000pF			EXF-P4102ZW	
C13, C14	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C15	A1283CM	Cap: fxd mica	390pF	±10%	100V	DM15C 561K1	not assigned
C16	A9068CN	Cap: fxd mica	470pF	±10%	100V	DM15C 471K1	
C17	A1831CF	Cap: fxd polye flm	1000pF	±10%	50V	501N5002-102K	
C18~C20	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C21~C23, C30	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C51	A1004CM	Cap: fxd mica	2.2pF	±10%	100V	DM05C 1R2K1	
C52	A1259CM	Cap: fxd mica	27pF	±10%	100V	DM05C 220K1	
C53, C54							
C55	A1251CM	Cap: fxd mica	10pF	±10%	100V	DM05C 4R7K1	
C56, C57	A9373CA	Cap: fxd Al elect	220μF		35V	ECEA1VS221R	
C58, C59	A9360CA	Cap: fxd Al elect	47μF		35V	ECEA1VS470R	not assigned
C60	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C61	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C62	A9013CN	Cap: fxd mica	10pF	±10%	100V	DM05C 100K1	
C63	A9249CY	Cap: fxd polye flm	6800pF	±10%	50V	MFL5002-682K	
L1~L6	A9100MC	Inductor				ZBF253D-01	
D1, D2	A9249HD	Diode: Si				1S954	
D3, D4	A9248HD	Diode: Si				1S953	
D5, D6							
D7~D10	A9248HD	Diode: Si				1S953	
D11~D17	A9248HD	Diode: Si				1S953	not assigned
D51, D52	A9248HD	Diode: Si				1S953	
D53	A9146HL	Diode: module				1B4B41	
D54~D60	A9248HD	Diode: Si				1S953	
D61	A9248HD	Diode: Si				1S953	
Q1	A9340HQ	XSTR: Si NPN				2SC1815-Y	
Q2	A9338HQ	XSTR: Si PNP				2SA1015-Y	

5-2. AC Input Board Ass'y (for Models 2533E32 and 2533E33): B9278JA. (continued)

Item	Part No.	Part Name and Description			Remarks
Q3	A9340HQ	XSTR: Si NPN		2SC1815-Y	
Q4	A9338HQ	XSTR: Si PNP		2SA1015-Y	
Q51	A9452HQ	XSTR: Si NPN		2SC2235-O, Y	
Q52	A9477HQ	XSTR: Si PNP		2SA965-Y	
U1	A9235LA	IC: analog		LT1055CN8	7 elements
U2	A9200LA	IC: analog		OP-07CN	
U3	A9096HL	IC: NPN Darlington XSTR array		μPA 2004C	
U4	A9200LA	IC: analog		OP-07CN	
U5	A9235LA	IC: analog		LT1055CN8	
U51, U52	A9235LA	IC: analog		LT1055CN8	7 elements MOS
U53	A9104LA	IC: +12 V voltage regulator		μPC14312H	
U54	A9213LA	IC: -12 V voltage regulator		NJM79L12	
U55	A9096HL	IC: NPN Darlington XSTR array		μPA2004C	
U56	A9148LM	IC: digital		TC4555BP	
PC1	A9073HL	Photo coupler		PC837	
CT1	B9278LR	Trans: CT			
RL1	A9260MR	Relay		DS2E-S-DC 5V	
RL2, RL3	A9282MR	Relay		ADB119	
RL51~RL54	A9282MR	Relay		ADB119	
CN1	A9460KP	Conn.		5281-3A	3P
CN2, CN3	A9244KP	Conn.		5045-03A	3P
CN4	A9246KP	Conn.		5045-02A	2P
CN5	A9159KP	Conn.		PS-30PA-D4LT1-PN1-K	30P
TP1~TP3	A9574KP	Test point		VTC-1-1	
	A9051KP	Feed through	(2 pcs)	FT-E-15	for U53
	A9177KH	Heat sink	(1 pc)	TYPE SB-7	
	B9278KA	PWB	(1 pc)		
	A9799KP	Edge saddle	(1 pc)	EDS-1208U	
	B9278DL	Plate	(1 pc)		
	B9278DM	Gasket	(2 pcs)		
	B9278DR	Cover	(1 pc)		
	B9278DS	Cover	(1 pc)		
	B9278DT	Plate ass'y	(1 pc)		
	A9599XK	Heat shrinkable tube			
	Y9305LB	Screw: M3 X 5	(7 pcs)		
	Y9435LB	Screw: M4 X .35	(1 pc)		
	Y9401BB	Nut: M4	(1 pc)		




Figure 5-3a. Sub Board Ass'y (for Models 2533E42 and 2533E43): B9278JE Schematic Diagram.





Figure 5-2b. AC Input Board Ass'y (for Models 2533E32 and 2533E33): B9278JA Components Location Diagram.

5-2. AC Input Board Ass'y (for Models 2533E32 and 2533E33): B9278JA.

(July 1992)

Item	Part No.	Part Name and Description						Remarks
R1	A9346RQ	Res: fxd met flm	11Ω	±0.1%	¼W	RN70S 11ΩB		not assigned
R2	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R3	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ		
R4	A9383RV	Res: var cermet	5kΩ	±20%	¼W	GF06X1 5kΩ		
R5	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ		
R6	A9071RG	Res: fxd met flm	8.2kΩ	±1%	¼W	LF¼ 8.2kΩF		
R7	A9178RK	Res: fxd met flm	100Ω	±0.1%	¼W	CFA 100ΩBT1		
R8	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R9, R10								
R11	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		4 elements
R12	A9005RG	Res: fxd met flm	15Ω	±1%	¼W	LF¼ 15ΩF		
R13	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		
R14	A9005RG	Res: fxd met flm	15Ω	±1%	¼W	LF¼ 15ΩF		
R15, R16	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R17	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R18	A9104RG	Res: fxd met flm	200kΩ	±1%	¼W	LF¼ 200kΩF		
R19	A9017RG	Res: fxd met flm	47Ω	±1%	¼W	LF¼ 47ΩF		
R20	A9080RG	Res: fxd met flm	20kΩ	±1%	¼W	LF¼ 20kΩF		
R21	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		4 elements
R22	A9005RG	Res: fxd met flm	15Ω	±1%	¼W	LF¼ 15ΩF		
R23	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		
R24	A9005RG	Res: fxd met flm	15Ω	±1%	¼W	LF¼ 15ΩF		
R25	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R26	A9087RG	Res: fxd met flm	39kΩ	±1%	¼W	LF¼ 39kΩF		
R27	A2226RM	Res: fxd met flm	500Ω	±0.1%	¼W	CFA 500ΩBT1		
R28	A1189RM	Res: fxd met flm	4.3kΩ	±1%	¼W	LF¼ 4.3kΩF		
R29	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R30	A9109RL	Res: module	470Ω	±5%	1/8 W	RKC1/8 B4 470ΩJ		
R31	A9075RG	Res: fxd met flm	12kΩ	±1%	¼W	LF¼ 12kΩF		not assigned
R51, R52	A9345RQ	Res: fxd met flm	480kΩ	±0.1%	¼W	RN70E 480kΩB		
R53	A9660RK	Res: fxd met flm	120kΩ	±0.1%	¼W	CFA 120kΩBT1		
R54	A9658RK	Res: fxd met flm	60kΩ	±0.1%	¼W	CFA 60kΩBT1		
R55	A2660RV	Res: var cermet	2kΩ	±20%	¼W	GF06X1 2kΩ		
R56	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ		
R57	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R58	A9087RG	Res: fxd met flm	39kΩ	±1%	¼W	LF¼ 39kΩF		
R59	A9660RK	Res: fxd met flm	120kΩ	±0.1%	¼W	CFA 120kΩBT1		
R60	A9384RV	Res: var cermet	100Ω	±20%	¼W	GF06X1 100Ω		
R61	A9661RK	Res: fxd met flm	13.3kΩ	±0.1%	¼W	CFA 13.3kΩBT1		not assigned
R62	A9183RL	Res: module				MRP1487		
R63	A9383RV	Res: var cermet	2kΩ	±20%	¼W	GF06X1 2kΩ		
R64, R65								
R66, R67	A9035RG	Res: fxd met flm	270Ω	±1%	¼W	LF¼ 270ΩF		
R68	A5788RM	Res: fxd met flm	22kΩ	±0.1%	¼W	CFA 22kΩBT1		
R69	A2223RM	Res: fxd met flm	100Ω	±0.1%	¼W	CFA100ΩBT1		
R70	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		
R71, R72	A9005RG	Res: fxd met flm	15Ω	±1%	¼W	LF¼ 15ΩF		
R73	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		
R74, R75	A9005RG	Res: fxd met flm	15Ω	±1%	¼W	LF¼ 15ΩF		




(July 1992)

Figure 5-3b. Sub Board Ass'y (for Models 2533E42 and 2533E43): B9278JE Components Location Diagram.

5-3. Sub Board Ass'y (for Models 2533E42 and 2533E43): B9278JE.


(July 1992)

Item	Part No.	Part Name and Description						Remarks
R1~R4 R5~R10	A9270RV	Res: var cermet	500kΩ	±20%	¼W	GF06X1	500Ω	not assigned
R11	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼	100kΩF	
R12	A9104RG	Res: fxd met flm	200kΩ	±1%	¼W	LF¼	200kΩF	
R13	A9111RG	Res: fxd met flm	390kΩ	±1%	¼W	LF¼	390kΩF	
R14	A9119RG	Res: fxd met flm	820kΩ	±1%	¼W	LF¼	820kΩF	
R15	A9053RG	Res: fxd met flm	1.5kΩ	±1%	¼W	LF¼	1.5kΩF	
R16	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼	150kΩF	
R17~R20								
R21	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼	100kΩF	
R22	A9104RG	Res: fxd met flm	200kΩ	±1%	¼W	LF¼	200kΩF	
R23	A9111RG	Res: fxd met flm	390kΩ	±1%	¼W	LF¼	390kΩF	not assigned
R24	A9119RG	Res: fxd met flm	820kΩ	±1%	¼W	LF¼	820kΩF	
R25	A9053RG	Res: fxd met flm	1.5kΩ	±1%	¼W	LF¼	1.5kΩF	
R26	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼	150kΩF	
R27~R30								
R31~R34	A9057RG	Res: fxd met flm	2.2kΩ	±1%	¼W	LF¼	2.2kΩF	
R35~R40								
R41	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼	100kΩF	
R42	A9104RG	Res: fxd met flm	200kΩ	±1%	¼W	LF¼	200kΩF	
R43	A9111RG	Res: fxd met flm	390kΩ	±1%	¼W	LF¼	390kΩF	
R44	A9119RG	Res: fxd met flm	820kΩ	±1%	¼W	LF¼	820kΩF	not assigned
R45	A9053RG	Res: fxd met flm	1.5kΩ	±1%	¼W	LF¼	1.5kΩF	
R46	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼	150kΩF	
R47~R50								
R51	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼	100kΩF	
R52	A9104RG	Res: fxd met flm	200kΩ	±1%	¼W	LF¼	200kΩF	
R53	A9111RG	Res: fxd met flm	390kΩ	±1%	¼W	LF¼	390kΩF	
R54	A9119RG	Res: fxd met flm	820kΩ	±1%	¼W	LF¼	820kΩF	
R55	A9053RG	Res: fxd met flm	1.5kΩ	±1%	¼W	LF¼	1.5kΩF	
R56	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼	150kΩF	not assigned
SW1, SW2	A9370SR	Sw: rtry				S-1031		
SW3	A9130SS	Sw: toggle				BP4L-G		
SW4, SW5	A9370SR	Sw: rtry				S-1031		
CN1~CN4	A9800KP	Conn				HLEM 10R-1		
	B9278KE	PWB	(1 pc)					



(July 1992)

Figure 5-4a. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF Schematic Diagram (1/2).



(July 1992)

Figure 5-4b. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF Schematic Diagram (2/2).




Figure 5-4c. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF Components Location Diagram.

5-4. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF.

(July 1992)

Item	Part No.	Part Name and Description						Remarks
R1	A9384RV	Res: var cermet	100Ω	±20%	¼W	GF06X1 100Ω	4 elements 4 elements	
R2	A9387RV	Res: var cermet	1kΩ	±20%	¼W	GF06X1 1kΩ		
R3	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ		
R4	A9270RV	Res: var cermet	500Ω	±20%	¼W	GF06X1 500Ω		
R5, R6	A9563RP	Res: fxd met flm	500kΩ	±0.1%	½W	RN70E 500kΩB		
R7	A9737RK	Res: fxd met flm	4.42kΩ	±0.1%	¼W	CFA 4.42kΩBT1		
R8	A9738RK	Res: fxd met flm	39.75kΩ	±0.1%	¼W	CFA 39.75kΩBT1		
R9	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF		
R10	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R11	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼ 150kΩF		not assigned
R12	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220SF		
R13	A9131RG	Res: fxd met flm	2.7MΩ	±2%	¼W	LF¼ 2.7MΩG		
R14	A9044RG	Res: fxd met flm	620Ω	±1%	¼W	LF¼ 620ΩF		
R15	A9157RL	Res: module	1kΩ X 4			MRP1361		
R16	A9041RL	Res: module	22kΩ	±5%	⅛ W	RKC⅛ B4 22kΩJ		
R17, R18	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF		
R19, R20	A9735RK	Res: fxd met flm	20Ω	±0.1%	¼W	CFA 20ΩBT1		
R21, R22	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R23, R24	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R25~R30								
R31	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ	not assigned	
R32	A9383RV	Res: var cermet	5kΩ	±20%	¼W	GF06X1 5kΩ		
R33	A9836RV	Res: var cermet	500kΩ	±20%	¼W	GF06X1 500kΩ		
R34	A9383RV	Res: var cermet	5kΩ	±20%	¼W	GF06X1 5kΩ		
R35	A9543RV	Res: var cermet	200Ω	±20%	¼W	GF06X1 200Ω		
R36	A9348RV	Res: var cermet	10kΩ	±20%	¼W	GF06X1 10kΩ		
R37	A9387RV	Res: var cermet	1kΩ	±20%	¼W	GF06X1 1kΩ		
R38	A9272RV	Res: var cermet	50kΩ	±20%	¼W	GF06X1 50kΩ		
R39	A9348RV	Res: var cermet	10kΩ	±20%	¼W	GF06X1 10kΩ		
R40								
R41	A9063RG	Res: fxd met flm	3.9kΩ	±1%	¼W	LF¼ 3.9kΩF	not assigned	
R42~R44	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼ 470ΩF		
R45	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R46	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R47	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R48	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R49, R50								
R51	A9085RG	Res: fxd met flm	33kΩ	±1%	¼W	LF¼ 33kΩF	not assigned	
R52	A9063RG	Res: fxd met flm	3.9kΩ	±1%	¼W	LF¼ 3.9kΩF		
R53	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R54	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R55	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R56~R59								
R60	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R61	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R62	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R63	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		

5-4. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF. (continued)

Item	Part No.	Part Name and Description						Remarks
R64								not assigned
R65	A9063RG	Res: fxd met flm	3.9kΩ	±1%	¼W	LF¼	3.9kΩF	not assigned
R66	A9085RG	Res: fxd met flm	33kΩ	±1%	¼W	LF¼	33kΩF	
R67	A9063RG	Res: fxd met flm	3.9kΩ	±1%	¼W	LF¼	3.9kΩF	
R68	A9112RG	Res: fxd met flm	430kΩ	±1%	¼W	LF¼	430kΩF	
R69	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼	15kΩF	
R70	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R71	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼	15kΩF	
R72	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R73, R74								not assigned
R75	A9075RG	Res: fxd met flm	12kΩ	±1%	¼W	LF¼	12kΩF	not assigned
R76	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R77	A9029RG	Res: fxd met flm	150Ω	±1%	¼W	LF¼	150ΩF	
R78	A9069RG	Res: fxd met flm	6.8kΩ	±1%	¼W	LF¼	6.8kΩF	
R79	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R80	A9178RK	Res: fxd met flm	100Ω	±0.1%	¼W	CFA	100ΩBT1	
R81	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼	100ΩF	
R82	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R83	A9075RG	Res: fxd met flm	12kΩ	±1%	¼W	LF¼	12kΩF	
R84, R85	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R86~R90								not assigned
R91	A9157RL	Res: module	1kΩ × 10			MRP1361		10 elements
R92	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼	470ΩF	not assigned
R93	A9111RG	Res: fxd met flm	390kΩ	±1%	¼W	LF¼	390kΩF	
R94	A9061RG	Res: fxd met flm	3.3kΩ	±1%	¼W	LF¼	3.3kΩF	
R95	A9264RK	Res: fxd met flm	4kΩ	±0.1%	¼W	CFA	4kΩBT1	
R96	A9331RQ	Res: fxd met flm	2.4kΩ	±0.1%	¼W	CFA	2.4kΩBT1	
R97	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼	100ΩF	
R98~R100								not assigned
R101	A9827RK	Res: fxd met flm	1.044kΩ	±0.1%	¼W	CFA	1.044kΩBT1	not assigned
R102	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼	100ΩF	
R103, R104	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R105, R106	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼	100ΩF	
R107	A9828RK	Res: fxd met flm	116Ω	±0.1%	¼W	CFB	116ΩBT1	
R108	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R109	A9053RG	Res: fxd met flm	1.5kΩ	±1%	¼W	LF¼	1.5kΩF	
R110	A9076RG	Res: fxd met flm	13kΩ	±1%	¼W	LF¼	13kΩF	
R111	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼	10ΩF	
R112~R114								not assigned
R115	A9112RG	Res: fxd met flm	430kΩ	±1%	¼W	LF¼	430kΩF	not assigned
R116	A9042RG	Res: fxd met flm	510Ω	±1%	¼W	LF¼	510ΩF	
R117	A9088RG	Res: fxd met flm	43kΩ	±1%	¼W	LF¼	43kΩF	
R118~R120	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼	10kΩF	
R121	A9103RG	Res: fxd met flm	180kΩ	±1%	¼W	LF¼	180kΩF	
C1	A9019CN	Cap: fxd mica	33pF	±10%	100V	DM05C	330K1	
C2	A9005CN	Cap: fxd mica	2.2pF	±10%	100V	DM05C	2R2K1	

5-4. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF. (continued)

Item	Part No.	Part Name and Description					Remarks
C3	A9013CN	Cap: fxd mica	10pF	±10%	100V	DM05C 100K1	
C4, C5	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C6, C7	A9444CA	Cap: fxd Al elect	100μF	±20%	35V	ECEA1VU101	
C8	A9254CY	Cap: fxd polye flm	0.047μF	±10%	50V	MFL5002-473K	
C9, C10	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C11, C12 C13~C20	A9445CA	Cap: fxd Al elect	220μF	±20%	35V	ECEA1VU221	not assigned
C21	A9009CL	Cap: module	1000pF X 4			EXF-P4102ZW	
C22~C27	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C28	A9367CY	Cap: fxd polye flm	0.22μF	±10%	63V	553M6302-224K	
C29	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C30	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K	
C31	A9365CY	Cap: fxd polye flm	0.068μF	±10%	63V	553M6302-683K	
C32, C33 C34~C39	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C40	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F 104Z50	
C41	A9365CY	Cap: fxd polye flm	0.068μF	±10%	63V	553M6302-683K	
C42	A9026CN	Cap: fxd mica	120pF	±10%	100V	DM05C 121K1	
C43, C44	A9445CA	Cap: fxd Al elect	220μF	±20%	35V	ECEA1VU221	
C45	A9248CY	Cap: fxd polye flm	4700pF	±10%	50V	MFL5002-472K	
C46	A9069CN	Cap: fxd mica	560pF	±10%	100V	DM15C 561K1	
C47	A9249CY	Cap: fxd polye flm	6800pF	±10%	50V	MFL5002-682K	
C48	A9365CY	Cap: fxd polye flm	0.068μF	±10%	63V	553M6302-683K	
C49, C50							not assigned
C51, C52	A9369CY	Cap: fxd polye flm	0.47μF	±10%	63V	553M6302-474K	
C53, C54	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C55	A9254CY	Cap: fxd polye flm	0.047μF	±10%	50V	MFL5002-473K	
C56, C57	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F 104Z50	
L1, L2	A9100ML	Inductor				ZBF-25D-01	
D1	A9248HD	Diode: Si				1S953	
D2, D3	A9182HL	Diode: array				MC-932	
D4, D5	A9302HD	Diode: zener				RD6.8E-B	
D6	A9182HL	Diode: array				MC-932	
D7, D8	A9302HD	Diode: zener				RD6.8E-B	
D9	A9092HL	Diode: module				1G4B41	
D10							
D11~D20							
D21, D11	A9182HL	Diode: array				MC-932	
D23, D24	A9306HD	Diode: zener				RD10E-B	
D25~D30	A9182HL	Diode: array				MC-932	
D31~D34	A9182HL	Diode: array				MC-932	

5-4. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF. (continued)

Item	Part No.	Part Name and Description		Remarks
Q1	A9340HQ	XSTR: Si NPN	2SC1815-Y	not assigned
Q2	A9454HQ	XSTR: Si NPN	2SC2690-A	
Q3	A9455HQ	XSTR: Si PNP	2SA1220-A	
Q4~Q10				
Q11	A9477HQ	XSTR: Si PNP	2SA965-Y	
Q12	A9454HQ	XSTR: Si NPN	2SC2690-A	not assigned
Q13	A9452HQ	XSTR: Si NPN	2SC2235-Y	
Q14	A9455HQ	XSTR: Si PNP	2SA1220-A	
Q15, Q16	A9477HQ	XSTR: Si PNP	2SA965-Y	
Q17	A9454HQ	XSTR: Si NPN	2SC2690-A	
Q18	A9455HQ	XSTR: Si PNP	2SA1220-A	not assigned
Q19, Q20	A9477HQ	XSTR: Si PNP	2SA965-Y	
Q21	A9452HQ	XSTR: Si NPN	2SC2235-Y	
Q22	A9477HQ	XSTR: Si PNP	2SA965-Y	
Q23	A9452HQ	XSTR: Si NPN	2SC2235-Y	
Q24	A9477HQ	XSTR: Si PNP	2SA965-Y	not assigned
U1	A9105LA	IC: -12V voltage regulator	μPC7912H	
U2	A9104LA	IC: +12V voltage regulator	μPC7812H	
U3	A9235LA	IC: analog	LT1055CN8	
U4	A9201LA	IC: analog	HI-508-5	
U5	A9218LA	IC: analog	LT1037CN8	not assigned
U6~U10				
U11	A9229LA	IC: analgo	LT1007CN8	
U12	A9259LA	IC: analog	LT1013CN8	
U13	A9218LA	IC: analog	LT1037CN8	
U14	A9259LA	IC: analog	LT1013CN8	not assigned
U15	A9218LA	IC: analog	LT1037CN8	
U16~U19	A9261LA	IC: analog	TL317LP	
U20				
U21	A9201LA	IC: analog	HI-508-5	MOS
U22	A9229LA	IC: analog	LT1007CN8	
U23	A9218LA	IC: analog	LT1037CN8	
U24	A9096HL	IC: NPN Darlington XSTR array	μPC2004C	
U25	A9200LA	IC: analog	OP-07CN8	
U26	A9058LM	IC: digital	TC4047BP	not assigned
U27	A9225LA	IC: analog	μPC393C	
PC1	A9073HL	Photo coupler	PC5073	
RL1	A9251MR	Relay	DS1E-S-DC12V	
RL2	A9259MR	Relay	DS1E-S-DC5V	
CN1~CN3	A9244KP	Conn	5045-03A	3P
CN4	A9641KP	Conn	HLEM-10S-1	10P
CN5	A9244KP	Conn	5045-03A	3P
CN6	A9641KP	Conn	HLEM-10S-1	10P
CN7	A9159KP	Conn	PS-30PA-D4LT1-PN1-K	30P
CN8~CN10	A9246KP	Conn	5045-02A	2P

5-4. DC Input Board Ass'y (for Models 2533E42 and 2533E43): B9278JF. (continued)

Item	Part No.	Part Name and Description		Remarks
TP1~TP8	A9574KP	Test point	VTC-1-1	
	B9278TF	Sheet ass'y	(1 pc)	
	B9278TR	Plate ass'y	(1 pc)	
	B9278TS	Plate	(1 pc)	
	B9278TT	Plate	(1 pc)	
	B9278TU	Plate	(1 pc)	
	B9278TW	Bracket	(1 pc)	
	B9278TX	Bracket	(1 pc)	
	Y9304LS	Screw: M3 X 4	(18 pcs)	
	Y9720YA	Spacer	(4 pcs)	
	B9278KF	PWB	(1 pc)	




Figure 5-5a. RMS Board Ass'y: B9278JB Schematic Diagram.




Figure 5-5b. RMS Board Ass'y: B9278JB Components Location Diagram.

5-5. RMS Board Ass'y: B9278JB.

(July 1992)

Item	Part No.	Part Name and Description					Remarks
R1, R2	A9543RV	Res: var cermet	200Ω	±20%	¼W	GF06X1 200Ω	4 elements
R3	A9348RV	Res: var cermet	10kΩ	±20%	¼W	GF06X1 10kΩ	
R4	A9272RV	Res: var cermet	50kΩ	±20%	¼W	GF06X1 50kΩ	
R5	A9113RG	Res: fxd met flm	470kΩ	±1%	¼W	LF¼ 470kΩF	
R6	A9086RG	Res: fxd met flm	36kΩ	±1%	¼W	LF¼ 36kΩF	
R7, R8	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF	
R9	B9278LZ	Res: module	5kΩ X 4			MRP1492	
R10	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼ 470ΩF	
R11	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼ 470ΩF	
R12	A9310RN	Res: fxd met flm	25kΩ	±0.1%	1/8 W	RN60E 25kΩB	4 elements
R13	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF	
R14	A9123RQ	Res: fxd met flm	20kΩ	±0.1%	1/8 W	RN60R 20kΩB	
R15	B9278LZ	Res: module	5kΩ X 4			MRP1492	
R16	A9142RQ	Res: fxd met flm	12kΩ	±0.1%	1/8 W	RN60R 12kΩB	
R17	A9057RG	Res: fxd met flm	2.2kΩ	±1%	¼W	LF¼ 2.2kΩF	
R18	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF	
R19, R20	A9029RG	Res: fxd met flm	150Ω	±1%	¼W	LF¼ 150ΩF	
R21, R22	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼ 470ΩF	2 elements
R23	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF	
R24	A9662RK	Res: fxd met flm	9.65kΩ	±0.1%	1/8 W	SFA 9.65kΩBT11	
R25	A9133RQ	Res: fxd met flm	15kΩ	±0.1%	1/8 W	SFA 15kΩBT11	
R26	A9178RL	Res: module	10kΩ X 2			MRP1436	
R27	A9017RG	Res: fxd met flm	47Ω	±1%	¼W	LF¼ 47ΩF	
R28	A9057RG	Res: fxd met flm	2.2kΩ	±1%	¼W	LF¼ 2.2kΩF	
R29	A9656RK	Res: fxd met flm	20kΩ	±0.1%	¼W	CFA 20kΩBT1	
R30	A9651RK	Res: fxd met flm	5kΩ	±0.1%	¼W	CFA 5kΩBT1	
R31	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF	not assigned
R32	A9096RG	Res: fxd met flm	91kΩ	±1%	¼W	LF¼ 91kΩF	
R33	A9112RG	Res: fxd met flm	430kΩ	±1%	¼W	LF¼ 430kΩF	
R34~R40							
R41	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ	
R42	A9543RV	Res: var cermet	200Ω	±20%	¼W	GF06X1 200Ω	
R43	A9113RG	Res: fxd met flm	470kΩ	±1%	¼W	LF¼ 470kΩF	
R44	A9008RG	Res: fxd met flm	20Ω	±1%	¼W	LF¼ 20ΩF	
R45	A9654RK	Res: fxd met flm	11kΩ	±0.1%	¼W	CFA 11kΩBT1	
R46	A9176RL	Res: module	5k, 10k X 3			MRP1434	
R47~R50							not assigned
R51	A9050RG	Res: fxd met flm	1.1kΩ	±1%	¼W	LF¼ 1.1kΩF	4 elements
R52	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF	
R53, R54	A9061RG	Res: fxd met flm	3.3kΩ	±1%	¼W	LF¼ 3.3kΩF	
R55, R56	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF	
R57	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF	
R58	A9050RG	Res: fxd met flm	1.1kΩ	±1%	¼W	LF¼ 1.1kΩF	
R59, R60	A9061RG	Res: fxd met flm	3.3kΩ	±1%	¼W	LF¼ 3.3kΩF	

5-5. RMS Board Ass'y: B9278JB. (continued)


Item	Part No.	Part Name and Description					Remarks
R61, R62	A9037RG	Res: fxd met flm	330Ω	±1%	¼W	LF¼ 330ΩF	not assigned
R63	A9063RG	Res: fxd met flm	3.9kΩ	±1%	¼W	LF¼ 3.9kΩF	
R64	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF	
R65	A9053RG	Res: fxd met flm	1.5kΩ	±1%	¼W	LF¼ 1.5kΩF	
R66, R67	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF	
R68	A9067RG	Res: fxd met flm	5.6kΩ	±1%	¼W	LF¼ 5.6kΩF	
R69	A9057RG	Res: fxd met flm	2.2kΩ	±1%	¼W	LF¼ 2.2kΩF	
R70	A9067RG	Res: fxd met flm	5.6kΩ	±1%	¼W	LF¼ 5.6kΩF	
R71	A9067RG	Res: fxd met flm	5.6kΩ	±1%	¼W	LF¼ 5.6kΩF	
R72~R80							
R81	A9387RV	Res: var cermet	1kΩ	±20%	¼w	GF06X1 1kΩ	not assigned
R82	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ	
R83	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF	
R84	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF	
R85	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF	
R86	A9022RG	Res: fxd met flm	75Ω	±1%	¼W	LF¼ 75ΩF	
R87	A9078RG	Res: fxd met flm	16kΩ	±1%	¼W	LF¼ 16kΩF	
R88	A9086RG	Res: fxd met flm	36kΩ	±1%	¼W	LF¼ 36kΩF	
R89	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF	
R90	A9656RK	Res: fxd met flm	20kΩ	±0.1%	¼W	CFA 20kΩBT1	
R91	A9651RK	Res: fxd met flm	5kΩ	±0.1%	¼W	CFA 5kΩBT1	not assigned
R92	A9096RG	Res: fxd met flm	91kΩ	±1%	¼W	LF¼ 91kΩF	
R93	A9112RG	Res: fxd met flm	430kΩ	±1%	¼W	LF¼ 430kΩF	
R94~R100							
R101	A9387RV	Res: var cermet	1kΩ	±20%	¼W	GF06X1 1kΩ	
R102	A9362RV	Res: var cermet	100kΩ	±20%	¼W	GF06X1 100kΩ	
R103	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF	
R104	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF	
R105	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF	
R106	A9022RG	Res: fxd met flm	75Ω	±1%	¼W	LF¼ 75ΩF	
R107	A9078RG	Res: fxd met flm	16kΩ	±1%	¼W	LF¼ 16kΩF	
R108	A9086RG	Res: fxd met flm	36kΩ	±1%	¼W	LF¼ 36kΩF	
R109	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF	not assigned
R110	A9656RK	Res: fxd met flm	20kΩ	±0.1%	¼W	CFA 20kΩBT1	
R111	A9651RK	Res: fxd met flm	5kΩ	±0.1%	¼W	CFA 5kΩBT1	
R112	A9096RG	Res: fxd met flm	91kΩ	±1%	¼W	LF¼ 91kΩF	
R113	A9112RG	Res: fxd met flm	430kΩ	±1%	¼W	LF¼ 430kΩF	
C1	A9024CV	Cap: var cer	70pF	max.		ECE-12W70P40	
C2	A9025CN	Cap: fxd mica	100pF	±10%	100V	DM05C 101K1	
C3~C10	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C11, C12	A9371CY	Cap: fxd polye flm	1μF	±10%	50V	553M5002 105K	
C13	A9033CN	Cap: fxd mica	390pF	±10%	100V	DM05C 391K1	
C14, C15	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	not assigned
C16	A9233CT	Cap: fxd Ta elect	1μF		35V	CS90E-1V-1R000-R58	
C17, C18	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	

5-5. RMS Board Ass'y: B9278JB. (continued)


Item	Part No.	Part Name and Description				Remarks
C19	A9233CT	Cap: fxd Ta elect	1μF	35V	CS90E-1V-1R000-R58	
C20	A9248CY	Cap: fxd polye flm	4700pF ±10%	50V	MFL5002-472K	
C21	A9229CY	Cap: fxd polye flm	0.1μF ±10%	100V	ECQ-E 1104KZ	
C22	A9233CT	Cap: fxd Ta elect	1μF	35V	CS90E-1V-1R000-R58	
C23, C24	A9335CA	Cap: fxd Al elect	33μF	35V	ECEA1VS4R7R	
C25~C28	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C29	A9244CY	Cap: fxd polye flm	1000pF ±10%	50V	MFL5002-102K	
C30	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C31	A9256CY	Cap: fxd polye flm	0.068μF ±10%	50V	MFL5002-683K	
C32, C33	A9368CY	Cap: fxd polye flm	0.33μF ±10%	63V	553M6302 334K	
C34	A9370CY	Cap: fxd polye flm	0.68μF ±10%	50V	553M5002 684K	not assigned
C35	A9371CY	Cap: fxd polye flm	1μF ±10%	50V	553M5002 105K	
C36, C37	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C38	A9244CY	Cap: fxd polye flm	1000pF ±10%	50V	MFL5002-102K	
C39	A9028CN	Cap: fxd mica	180pF ±10%	100V	DM05C 181K1	
C40						
C41~C44	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C45, C46	A9371CY	Cap: fxd polye flm	1μF ±10%	50V	553M5002 105K	
C47~C50						
C51, C52	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C53, C54	A9371CY	Cap: fxd polye flm	1μF ±10%	50V	553M5002 105K	
C55, C56	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C57	A9256CY	Cap: fxd polye flm	0.068μF ±10%	50V	MFL5002-683K	
C58	A9368CY	Cap: fxd polye flm	0.33μF ±10%	63V	553M6302 334K	
C59	A9244CY	Cap: fxd polye flm	1000pF ±10%	50V	MFL5002-102K	
C60	A9368CY	Cap: fxd polye flm	0.33μF ±10%	63V	553M6302 334K	
C61	A9370CY	Cap: fxd polye flm	0.68μF ±10%	50V	553M5002 684K	
C62	A9371CY	Cap: fxd polye flm	1μF ±10%	50V	553M5002 105K	
C63~C70						
C71, C72	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C73, C74	A9371CY	Cap: fxd polye flm	1μF ±10%	50V	553M5002 105K	
C75, C76	A9114CC	Cap: fxd cer	0.1μF	50V	RPE132-305F104Z50	
C77	A9256CY	Cap: fxd polye flm	0.068μF ±10%	50V	MFL5002-683K	
C78	A9368CY	Cap: fxd polye flm	0.33μF ±10%	63V	553M6302 334K	
C79	A9244CY	Cap: fxd polye flm	1000pF ±10%	50V	MFL5002-102K	
C80	A9368CY	Cap: fxd polye flm	0.33μF ±10%	63V	553M6302 334K	
C81	A9370CY	Cap: fxd polye flm	0.68μF ±10%	50V	553M5002 684K	
C82	A9371CY	Cap: fxd polye flm	1μF ±10%	50V	553M5002 105K	
C83~C90						
C91, C92	A9335CA	Cap: fxd Al elect	33μF	35V	ECEA1VS330R	not assigned
D1, D2	A9304HD	Diode: zener			RD8.2E-B	
D3, D4	A9248HD	Diode: Si			1S953	
D5	A9229HD	Diode: zener			RD4.7E-B	

5-5. RMS Board Ass'y: B9278JB. (continued)

Item	Part No.	Part Name and Description		Remarks
D6, D7	A9362HD	Diode: Schottky	1SS237(1)	not assigned
D8, D9	A9248HD	Diode: Si	1S953	
D10				
D11~D16	A9248HD	Diode: Si	1S953	not assigned
D17~D20				
D21~D30	A9248HD	Diode: Si	1S953	not assigned
D31, D32	A9248HD	Diode: Si	1S953	
D33~D40				not assigned
D41~D44	A9248HD	Diode: Si	1S953	
D45~D50				not assigned
D51~D54	A9248HD	Diode: Si	1S953	
D55~D60				not assigned
D61	A9248HD	Diode: Si	1S953	
D62~D70				not assigned
D71, D72	A9248HD	Diode: Si	1S953	
D73, D74	A9180HD	Diode: zener	RD4.3E-B	CMOS
Q1	A9340HQ	XSTR: Si NPN	2SC1815-Y	
Q2	A9338HQ	XSTR: Si PNP	2SA1015-Y	
Q3, Q4	A9340HQ	XSTR: Si NPN	2SC1815-Y	
U1	A9229LA	IC: analog	LT1007CN8	CMOS
U2	A9173LA	IC: analog	SD5000N	
U3, U4	A9229LA	IC: analog	LT1007CN8	
U5	A9027LN	IC: digital	MM74HC139N	
U6	A9218LA	IC: analog	LT1037CN8	CMOS
U7	A9086LN	IC: digital	TC74HC14P	
U8	A9075LM	IC: digital	TC4069BP	
U9	A9195LA	IC: analog	NJM4558D-SP	
U10	A9200LA	IC: analog	OP-07CN	64P
U11	A9188LA	IC: analog	LT1012CN8	
U12	A9200LA	IC: analog	OP-07CN	
U13	A9235LA	IC: analog	LT1055CN8	
U14, U15	A9019LA	IC: analog	LM339N	
U16	A9026LE	IC: RMS-DC converter	AD637JD	
U17	A9188LA	IC: analog	LT1012CN8	
U18	A9026LE	IC: RMS-DC converter	AD637JD	
U19	A9188LA	IC: analog	LT1012CN8	
RL1	A9260MR	Relay	DS2E-S-DC5V	
RL2	A9259MR	Relay	DS1E-S-DC5V	
RL3, RL4	A9260MR	Relay	DS2E-S-DC5V	
CN1	A9708KP	Conn.	PCN10A-64P-2.54DS	64P
TP1~TP6	A9574KT	Test point	VTC-1-1	
	B9278KB	PWB	(1 pc)	



IM 2533E-03E



(July 1992)

Figure 5-6b. SUM MPX Board Ass'y: B9278JC Components Location Diagram.


5-6. SUM MPX Board Ass'y: B9278JC.

(July 1992)

Item	Part No.	Part Name and Description						Remarks
R1	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF	2 elements	
R2	A9178RL	Res: module	10kΩ X 2			MRP1436		
R3	A9177RL	Res: module	10kΩ X 6			MRP1435	6 elements	
R4	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R5	A9178RL	Res: module	10kΩ X 2			MRP1436	2 elements	
R6	A9177RL	Res: module	10kΩ X 6			MRP1435		
R7	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF	2 elements	
R8	A9178RL	Res: module	10kΩ X 2			MRP1436		
R9	A9177RL	Res: module	10kΩ X 6			MRP1435	6 elements	
R10	A9102RL	Res: module	100kΩ	±5%	⅛ W	RKC⅛ B4 100kΩJ		
R11~R20	A9102RL	Res: module	100kΩ	±5%	⅛ W	RKC⅛ B4 100kΩJ	4 elements	
R21	A9102RL	Res: module	100kΩ	±5%	⅛ W	RKC⅛ B4 100kΩJ		
R22, R23	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF	4 elements	
R24	A9041RL	Res: module	22kΩ	±5%	⅛ W	RKC⅛ B4 22kΩJ		
R25	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼ 470ΩF		
R26, R27	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		
R28	A9041RG	Res: fxd met flm	470Ω	±1%	¼W	LF¼ 470ΩF		
R29, R30	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		
R31, R32	A9041RL	Res: module	22kΩ	±5%	⅛ W	RKC⅛ B4 22kΩJ		
R33~R38	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R39, R40	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R41	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
C1, C2	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C3	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K		
C4, C5	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C6	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K		
C7, C8	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C9	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K		
C10	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C11~C13	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C14	A9354CA	Cap: fxd Al elect	100μF		16V	ECEA1CS101R		
C15~C20	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C21, C22	A9335CA	Cap: fxd Al elect	33μF		35V	ECEA1VS330R		
D1~D10	A9248HD	Diode: Si				1S953		
D11~D20	A9248HD	Diode: Si				1S953		
D21~D28	A9248HD	Diode: Si				1S953		
Q1~Q10	A9413HQ	FET				2SK117-BL		
Q11~Q20	A9413HQ	FET				2SK117-BL		
Q21~Q30	A9413HQ	FET				2SK117-BL		

5-6. SUM MPX Board Ass'y: B9278JC. (continued)

Item	Part No.	Part Name and Description		Remarks
Q31~Q36	A9413HQ	FET	2SK117-BL	
Q37	A9452HQ	XSTR: Si NPN	2SC2235-O, Y	
Q38	A9340HQ	XSTR: Si NPN	2SC1815-Y	
Q39	A9452HQ	XSTR: Si NPN	2SC2235-O, Y	
Q40	A9340HQ	XSTR: Si NPN	2SC1815-Y	
U1~U6	A9200LA	IC: analog	OP-07CN	CMOS
U7~U10	A9019LA	IC: analog	LM339N	
U11~U15	A9019LA	IC: analog	LM339N	
U16~U18	A9031LN	IC: digital	MM74HC154N	
U19, U20	A9002LA	IC: analog	OP-07CN	
U21	A9002LA	IC: analog	OP-07CN	
RL1~RL3	A9260MR	Relay	DS2E-S-DC5V	
CN1	A9708KP	Conn.	PCN10A-64P-2.54DS	
	B9278KC	PWB	(1 pc)	64P



(July 1992)

Figure 5-7a. A/D Converter Board Ass'y: B9278JD Schematic Diagram.




Figure 5-7b. A/D Converter Board Ass'y: B9278JD Components Location Diagram.

5-7. A/D Converter Board Ass'y: B9278JD.

(July 1992)

Item	Part No.	Part Name and Description						Remarks
R1, R2 R3~R10	A9130RL	Res: module	22Ω	±5%	¼W	RKC¼B4S 22ΩJ		4 elements not assigned
R11~R18								not assigned 4 elements
R19	A9043RL	Res: module	4.7kΩ	±5%	⅛W	RKC⅛B4 4.7kΩJ		
R20	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R21~R23	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R24	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R25	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R26	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		
R27	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R28	A9043RL	Res: module	4.7kΩ	±5%	⅛W	RKC⅛B4 4.7kΩJ		4 elements
R29	A9387RV	Res: var cermet	1kΩ	±20%	¼W	GF06X1 1kΩ		
R30	A9271RV	Res: var cermet	20kΩ	±20%	¼W	FG06X1 20kΩ		
R31	A9387RV	Res: var cermet	1kΩ	±20%	¼W	GF06X1 1kΩ		
R32	A9271RV	Res: var cermet	20kΩ	±20%	¼W	GF06X1 20kΩ		
R33	A9387RV	Res: var cermet	1kΩ	±20%	¼W	GF06X1 1kΩ		
R34	A9271RV	Res: var cermet	20kΩ	±20%	¼W	GF06X1 20kΩ		
R35	A9348RV	Res: var cermet	10kΩ	±20%	¼W	GF06X1 10kΩ		
R36	A9659RK	Res: fxd met flm	74.5kΩ	±0.1%	¼W	CFA 74.5kΩBT1		
R37	A9086RG	Res: fxd met flm	36kΩ	±1%	¼W	LF¼ 36kΩF		
R38	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R39	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R40	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		
R41	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R42	A9725RK	Res: fxd met flm	50kΩ	±0.1%	¼W	CFA 50kΩBT1		
R43	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF		
R44	A9089RG	Res: fxd met flm	47kΩ	±1%	¼W	LF¼ 47kΩF		
R45	A9659RK	Res: fxd met flm	74.5kΩ	±0.1%	¼W	CFA 74.5kΩBT1		
R46	A9086RG	Res: fxd met flm	36kΩ	±1%	¼W	LF¼ 36kΩF		
R47	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R48	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R49	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		
R50	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R51	A9725RK	Res: fxd met flm	50kΩ	±0.1%	¼W	CFA 50kΩBT1		
R52	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF		
R53	A9089RG	Res: fxd met flm	47kΩ	±1%	¼W	LF¼ 47kΩF		
R54	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R55	A9086RG	Res: fxd met flm	36kΩ	±1%	¼W	LF¼ 36kΩF		
R56	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R57	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R58	A9659RK	Res: fxd met flm	74.5kΩ	±0.1%	¼W	CFA 74.5kΩBT1		
R59	A9051RG	Res: fxd met flm	1.2kΩ	±1%	¼W	LF¼ 1.2kΩF		
R60	A9083RG	Res: fxd met flm	27kΩ	±1%	¼W	LF¼ 27kΩF		
R61	A9083RG	Res: fxd met flm	27kΩ	±1%	¼W	LF¼ 27kΩF		
R62	A9051RG	Res: fxd met flm	1.2kΩ	±1%	¼W	LF¼ 1.2kΩF		
R63	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		

5-7. A/D Converter Board Ass'y: B9278JD. (continued)

Item	Part No.	Part Name and Description						Remarks
R64	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R65	A9725RK	Res: fxd met flm	50kΩ	±0.1%	¼W	CFA 50kΩBT1		
R66	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF		
R67	A9089RG	Res: fxd met flm	47kΩ	±1%	¼W	LF¼ 47kΩF		
C1	A9355CA	Cap: fxd Al elect	220μF		16V	ECEA1CS221R		
C2	A9025CN	Cap: fxd mica	100pF	±10%	100V	DM05C 101K1		
C3~C10	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C11	A9231CY	Cap: fxd polye flm	0.22μF	±10%	100V	ECQ-E 1224KZ		
C12	A9371CY	Cap: fxd polye flm	1μF	±10%	50V	553M5002 105K		
C13, C14	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C15	A9231CY	Cap: fxd polye flm	0.22μF	±10%	100V	ECQ-E 1224KZ		
C16, C17	A9371CY	Cap: fxd polye flm	1μF	±10%	50V	553M5002 105K		
C18	A9231CY	Cap: fxd polye flm	0.22μF	±10%	100V	ECQ-E 1224KZ		
C19, C20	A9335CA	Cap: fxd Al elect	33μF		35V	ECEA1VS330R		
C21	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K		
C22~C30	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C31~C33	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
L1~L10	A9100MC	Filter				ZBF253D-01		
L11~L20	A9100MC	Filter				ZBF253D-01		
L21~L23	A9100MC	Filter				ZBF253D-01		
D1~D3	A9248HD	Diode: Si				1S953		
D4, D5	A9307HD	Diode: zener				RD11E-B		
D6, D7	A9248HD	Diode: Si				1S953		
D8, D9	A9307HD	Diode: zener				RD11E-B		
D10	A9248HD	Diode: Si				1S953		
D11	A9248HD	Diode: Si				1S953		
D12, D13	A9307HD	Diode: zener				RD11E-B		
D14	A9305HD	Diode: zener				RD9.1E-B		
D15								not assigned
D16	A9248HD	Diode: Si				1S953		
Q1~Q4	A9340HQ	XSTR: Si NPN				2SC1815-Y		
Q5	A9338HQ	XSTR: Si PNP				2SA1015-Y		
U1	A9069LN	IC: digital				MM74HC393N		CMOS
U2, U3	A9014LN	IC: digital				MM74HC74N		CMOS
U4, U5	A9004LN	IC: digital				MM74HC08N		CMOS
U6	A9069LN	IC: digital				MM74HC393N		CMOS
U7	A9007LN	IC: digital				MM74HC14N		CMOS
U8	A9003LN	IC: digital				MM74HC04N		CMOS
U9	A9004LN	IC: digital				MM74HC08N		CMOS
U10	A9068LN	IC: digital				MM74HC390N		CMOS

5-7. A/D Converter Board Ass'y: B9278JD. (continued)

Item	Part No.	Part Name and Description		Remarks
U11	A9002LN	IC: digital	MM74HC02N	CMOS
U12, U13	A9032LE	IC: PWM A/D converter	μPC614D-2	MOS
U14	A9032LE	IC: PWM A/D converter	μPC614D-2	MOS
CN1	A9709KP	Conn.	PCN10A-32P-2.54DS	32P
CN2	A9708KP	Conn.	PCN10A-64P-2.54DS	64P
CN3	A9637KC	Conn.	57LE-40360-7700-D12	36P
TP1~TP5	A9574KP	Test point	VTC-1-1	
	B9278DX	Plate	(1 pc)	
	Y9308LB	Screw: M3 × 8	(2 pcs)	
	Y9310JB	Screw: M3 × 10	(2 pcs)	
	B9278KD	PWB	(1 pc)	




Figure 5-8a. Display Control Board Ass'y: B9278JH Schematic Diagram.




Figure 5-8b. Display Control Board Ass'y: B9278JH Components Location Diagram.

5-8. Display Control Board Ass'y: B9278JH.

(July 1992)

Item	Part No.	Part Name and Description					Remarks
R1~R4	A9118RL	Res: module	470Ω	±5%	¼W	RKC¼B4S 470ΩJ	4 elements
R5	A9071RL	Res: module	22kΩ	±5%	⅛W	RK⅛B8 22kΩJ	8 elements
R6	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF	
R7, R8	A9071RL	Res: module	22kΩ	±5%	⅛W	RK⅛B8 22kΩJ	8 elements
R9, R10	A9111RL	Res: module	1kΩ	±5%	¼W	RKC¼B4S 1kΩJ	4 elements
R11	A9071RL	Res: module	22kΩ	±5%	⅛W	RK⅛B8 22kΩJ	8 elements
R12~R15	A9118RL	Res: module	470Ω	±5%	¼W	RKC¼B4S 470ΩJ	4 elements
R16, R17	A9111RL	Res: module	1kΩ	±5%	¼W	RKC¼B4S 1kΩJ	4 elements
R18	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF	
R19	A9071RL	Res: module	22kΩ	±5%	⅛W	RK⅛B8 22kΩJ	8 elements
C1, C2	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C3	A9343CA	Cap: fxd Al elect	470μF		16V	ECEB1CS471R	
C4	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C5	A9343CA	Cap: fxd Al elect	470μF		16V	ECEB1CS471R	
C6~C8	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C9	A9343CA	Cap: fxd Al elect	470μF		16V	ECEB1CS471R	
C10	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
C11	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50	
Q1~Q10	A9477HQ	XSTR: Si PNP				2SA965	
Q11~Q16	A9477HQ	XSTR: Si PNP				2SA965	
U1, U2	A9145LM	LSI: programmable display controller				μPD8279C-5	MOS
U3	A9003LN	IC: digital				MM74HC04N	CMOS
U4	A9011LN	IC: digital				MM74HC32N	CMOS
U5	A9062LN	IC: digital				MM74HC365N	CMOS
U6	A9003LN	IC: digital				MM74HC04N	CMOS
U7	A9052LN	IC: digital				MM74HC245N	CMOS
U8	A9081LN	IC: digital				MM74HC273N	CMOS
U9	A9026LN	IC: digital				MM74HC138N	CMOS
U10	A9084LN	IC: digital				MM74HC4514N	CMOS
U11	A9047LN	IC: digital				MM74HC240N	CMOS
U12	A9084LN	IC: digital				MM74HC4514N	CMOS
U13	A9047LN	IC: digital				MM74HC240N	CMOS
U14~U20	A9131HL	XSTR: array				STA404A	
U21	A9131HL	XSTR: array				STA404A	
CN1	A9708KP	Conn.				PCN10A-64P-2.54DS	64P
CN2	A9114KP	Conn.				PS-40PA-D4LT1-PN1-K	40P
CN3	A9159KP	Conn.				PS-30PA-D4LT1-PN1-K	30P
	B9278KH	PWB	(1 pc)				




Figure 5-9a. CPU Board Ass'y: B9278JJ Schematic Diagram (1/2).

(July 1992)





Figure 5-9b. CPU Board Ass'y: B9278JJ Schematic Diagram (2/2).



(July 1992)


Figure 5-9c. CPU Board Ass'y: B9278JJ Components Location Diagram.

5-9. CPU Board Ass'y: B9278JJ.

(July 1992)


Item	Part No.	Part Name and Description						Remarks
R1	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF		
R2	A9081RG	Res: fxd met flm	22kΩ	±1%	¼W	LF¼ 22kΩF		
R3	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R4	A9076RG	Res: fxd met flm	13kΩ	±1%	¼W	LF¼ 13kΩF		
R5	A9057RG	Res: fxd met flm	2.2kΩ	±1%	¼W	LF¼ 2.2kΩF		
R6, R7	A9070RL	Res: module	4.7kΩ	±5%	1/8 W	RK1/8 B8 4.7kΩJ		8 elements
R8	A9022RL	Res: module	1kΩ	±5%	1/8 W	RK1/8 B8 1kΩJ		8 elements
R9	A9071RL	Res: module	22kΩ	±5%	1/8 W	RK1/8 B8 22kΩJ		8 elements
R10	A9108RG	Res: fxd met flm	300kΩ	±1%	¼W	LF¼ 300kΩF		
R11	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF		
R12, R13	A9071RL	Res: module	22kΩ	±5%	1/8 W	RK1/8 B8 22kΩJ		8 elements
C1, C2	A9354CA	Cap: fxd Al elect	100μF		16V	ECEA1CS101R		
C3~C10	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
C11~C18	A9114CC	Cap: fxd cer	0.1μF		50V	RPE132-305F104Z50		
D1	A9248HD	Diode: Si				1S953		
D2, D3	A9392HD	Diode: Schottky				S1S3M		
D4	A9248HD	Diode: Si				1S953		
U1	A9030LC	LSI: CPU				MSM80C85A		
U2	A9577LB	IC: digital				TL7700CP		
U3	A9007LN	IC: digital				MM74HC14N		CMOS
U4, U5	A9062LN	IC: digital				MM74HC365N		CMOS
U6	A9001LN	IC: digital				MM74HC00N		CMOS
U7	A9031LN	IC: digital				MM74HC154N		CMOS
U8	A9052LN	IC: digital				MM74HC245N		CMOS
U9	A9075LN	IC: digital				MM74HC573N		CMOS
U10	A9055LC	LSI: interrupt control unit				μPD71059C		
U11	A9047LN	IC: digital				MM74HC240N		CMOS
U12, U13	A9052LC	LSI: programmable timer, counter				μPD71054C		
(U14)	B9278NA	LSI: ROM ass'y				(μPD27C256D-20)		PGM'd not assigned
U15								
U16	A9051LC	LSI: parallel interface				μPD71055C		
U17	A9051LN	IC: digital				MM74HC244N		CMOS
U18	A9027LN	IC: digital				MM74HC139N		CMOS
U19	A9031LD	LSI: memory (SRAM)				HM6264LP-15		
U20	A9051LC	LSI: parallel interface				μPD71055C		
U21	A9051LN	IC: digital				MM74HC244N		CMOS
CN1, CN2	A9708KP	Conn.				PCN10A-64P-2.54DS		
SW1	A9130SS	Sw: DIP				DNP-4		4 elements
X1	A9105EX	Quartz resonator	6MHz			LQV6M00-02CG		
	A9575KC	IC socket	(2 pcs)			DICF-28A		for U14, U15
	A9576KC	IC socket	(1 pc)			DICF-40A		for U1
	B9278KJ	PWB	(1 pc)					

Note: U14 is not included in the components of this ass'y.



(July 1992)

Figure 5-10a. Display Board Ass'y: B9278JK Schematic Diagram.




(July 1992)

Figure 5-10b. Display Board Ass'y: B9278JK Components Location Diagram.

5-10. Display Board Ass'y: B9278JK.

(July 1992)

Item	Part No.	Part Name and Description				Remarks
R1~R10	A9009RG	Res: fxd met flm	22Ω	±1%	¼W LF¼ 22ΩF	
R11~R16	A9009RG	Res: fxd met flm	22Ω	±1%	¼W LF¼ 22ΩF	
D1~D10	A9120HP	Diode: 7 seg. LED			HDSP-5503	
D11~D19	A9120HP	Diode: 7 seg. LED			HOSP-5503	
D20	A9100HP	Diode: module			HLMP-2620	
D21~D26	A9100HP	Diode: module			HLMP-2620	
D27	A9099HP	Diode: LED			TLR124	red
D28, D29	A9075HP	Diode: LED			TLO124	orange
D30	G9037HL	Diode: LED			TLG124	green
D31, D32	G9037HL	Diode: LED			TLG124	green
D33	A9099HP	Diode: LED			TLR124	red
D34	A9119HP	Diode: module			GL-197H12	yellow
D35~D39						not assigned
D40	A9099HP	Diode: LED			TLR124	red
D41	A9119HP	Diode: module			GL-107H12	yellow
D42~D46						not assigned
D47~D50	A9248HD	Diode: Si			1S953	
D51~D54	A9248HD	Diode: Si			1S953	
SW1~SW7	A9204SP	Sw: push			TM3-01-L05	
SW8	A9203SP	Sw: push			TM1-01	
SW9, SW10	A9204SP	Sw: push			TM3-01-L05	
SW11~SW14	A9204SP	Sw: push			TM3-01-L05	
SW15	A9203SP	Sw: push			TM1-01	
SW16~SW20	A9204SP	Sw: push			TM3-01-L05	
SW21~SW23	A9204SP	Sw: push			TM3-01-L05	
SW24, SW25	A9203SP	Sw: push			TM1-01	
SW26	A9204SP	Sw: push			TM3-01-L05	
SW27, SW28	A9203SP	Sw: push			TM1-01	
SW29, SW30	A9204SP	Sw: push			TM3-01-L05	
SW31~SW40	A9204SP	Sw: push			TM3-01-L05	
SW41~SW44	A9204SP	Sw: push			TM3-01-L05	
SW45~SW48	A9203SP	Sw: push			TM1-01	
SW49, SW50	A9204SP	Sw: push			TM3-01-L05	
SW51	A9203SP	Sw: push			TM1-01	
CN1	A9266KP	Conn			PS-40PA-D4T1-PN1-K	40P
CN2	A9134KP	Conn			PS-30PA-D4T1-PN1-K	30P
	B9278FP	Spacer	(2 pcs)			
	B9278FQ	Spacer	(1 pc)			
	B9278KK	PWB	(1 pc)			



ASSY	B9278JL
PWB	B9278KL

Figure 5-11a. Mother Board Ass'y: B9278JL Schematic Diagram (1/2).





Figure 5-11b. Mother Board Ass'y: B9278JL Schematic Diagram (2/2).



(July 1992)

Figure 5-11c. Mother Board Ass'y: B9278JL Components Location Diagram.

5-11. Mother Board Ass'y: B9278JL.

(July 1992)

Item	Part No.	Part Name and Description			Remarks
CN1~CN5	A9710KP	Conn.		PCN10C-64S-2.54DSA	64P
CN6	A9711KP	Conn.		PCN10C-32S-2.54DSA	32P
CN7	A9710KP	Conn.		PCN10C-64S-2.54DSA	64P
CN8	A9711KP	Conn.		PCN10C-32S-2.54DSA	32P
CN9, CN10	A9710KP	Conn.		PCN10C-64S-2.54DSA	64P
CN11~CN13	A9710KP	Conn.		PCN10C-64S-2.54DSA	64P
CN14					not assigned
CN15~CN17	A9134KP	Conn.		PS-30PA-D4T1-PN1-K	30P
	A9418KP	Housing	(1 pc)	5197-10	
	A9243KP	Housing	(1 pc)	5051-03	
	A9374KP	Contact	(3 pcs)	5159T	for A9243KP
	A9449KP	Contact	(10 pcs)	5149T	for A9418KP
	B9278KL	PWB	(1 pc)		




Figure 5-12a. Power Supply Board Ass'y (for Models 2533E32 and 2533E33): B9278JM Schematic Diagram.





Figure 5-12b. Power Supply Board Ass'y (for Models 2533E32 and 2533E33): B9278JM Components Location Diagram.

5-12. Power Supply Board Ass'y (for Models 2533E32 and 2533E33): B9278JM.

(July 1992)


Item	Part No.	Part Name and Description				Remarks
R1	A9045RG	Res: fxd met flm	680Ω	±1%	¼W	LF¼ 680ΩF
R2	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF
R3	A9113RG	Res: fxd met flm	470kΩ	±1%	¼W	LF¼ 470kΩF
R4	A9080RG	Res: fxd met flm	20kΩ	±1%	¼W	LF¼ 20kΩF
R5	A9079RG	Res: fxd met flm	18kΩ	±1%	¼W	LF¼ 18kΩF
R6	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF
R7	A9009RG	Res: fxd met flm	22Ω	±1%	¼W	LF¼ 22ΩF
R8	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF
R9	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF
R10	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF
R11~R13	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF
R14	A9085RG	Res: fxd met flm	33kΩ	±1%	¼W	LF¼ 33kΩF
R15	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF
R16	A9270RV	Res: var cermet	500Ω	±20%	¼W	GF06X1 500Ω
C1	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K
C2	A9351CA	Cap: fxd Al elect	22μF		35V	ECEA1VS220R
C3~C5	A9250CY	Cap: fxd polye flm	0.01μF	±10%	50V	MFL5002-103K
C6, C7	A9373CA	Cap: fxd Al elect	220μF		35V	ECEA1VS221R
C8~C10	A9425CA	Cap: fxd Al elect	2200μF		25V	KME25VB2200
C11, C12	A9353CA	Cap: fxd Al elect	2200μF		35V	ECEA1VS222R
C13	A9406CA	Cap: fxd Al elect	6800μF		35V	ECES1VU682M
L1	A9084EC	Inductor				SKC-103
D1, D2	A9236HD	Diode: Si				F14A
D3	A9385HD	Diode: zener				S5S3M
D4, D5	A9115HL	Diode: module				4G4B41
Q1	A9340HQ	XSTR: Si NPN				2SC1815-Y
Q2	A9338HQ	XSTR: Si PNP				2SA1015-Y
Q3	A9401HQ	XSTR: Si PNP				2SA1010-L
U1	A9085LA	IC: analog				μPC271C
U2	A9115LA	IC: analog				HA17524P
U3	A9074LA	IC: -15V voltage regulator				μPC16315H
U4	A9073LA	IC: +15V voltage regulator				μPC14315H
CN1	A9244KP	Conn				5045-03A
CN2	A9447KP	Conn				5281-10A
CN3	A9244KP	Conn				5045-03A
CN4	A9462KP	Conn				5281-8A
TP1~TP5	A9574KP	Test point				VTC-1-1
	A9168KH	Heat sink	(3 pcs)			MC 245A-2M3
	Y9410XH	Stud	(2 pcs)			
	Y9406LB	Screw : M4x6	(2 pcs)			
	B9278KM	PWB	(1 pc)			for Q3, U3, U4



ASSY	B9278JN
PWB	B9278KN

(July 1992)

Figure 5-13a. Power Supply Board Ass'y (for Models 2533E42 and 2533E43): B9278JN Schematic Diagram.



(July 1992)

5-13. Power Supply Board Ass'y (for Models 2533E42 and 2533E43): B9278JN.

(July 1992)

Item	Part No.	Part Name and Description						Remarks
R1	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R2	A9270RV	Res: var cermet	500Ω	±20%	¼W	GF06X1 500Ω		
R3	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R4	A9045RG	Res: fxd met flm	680Ω	±1%	¼W	LF¼ 680ΩF		
R5	A9113RG	Res: fxd met flm	470kΩ	±1%	¼W	LF¼ 470kΩF		
R6	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R7	A9079RG	Res: fxd met flm	18kΩ	±1%	¼W	LF¼ 18kΩF		
R8	A9080RG	Res: fxd met flm	20kΩ	±1%	¼W	LF¼ 20kΩF		
R9	A9097RG	Res: fxd met flm	100kΩ	±1%	¼W	LF¼ 100kΩF		
R10	A9009RG	Res: fxd met flm	22Ω	±1%	¼W	LF¼ 22ΩF		
R11	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF		
R12	A9033RG	Res: fxd met flm	220Ω	±1%	¼W	LF¼ 220ΩF		
R13~R15	A9065RG	Res: fxd met flm	4.7kΩ	±1%	¼W	LF¼ 4.7kΩF		
R16	A9085RG	Res: fxd met flm	33kΩ	±1%	¼W	LF¼ 33kΩF		
R17	A9506RA	Res: fxd ww	0.1Ω	±10%	2W	ERW-2PKR10		
R18~R20								not assigned
R21	A9061RG	Res: fxd met flm	3.3kΩ	±1%	¼W	LF¼ 3.3kΩF		
R22	A9079RG	Res: fxd met flm	18kΩ	±1%	¼W	LF¼ 18kΩF		
R23	A9076RG	Res: fxd met flm	13kΩ	±1%	¼W	LF¼ 13kΩF		
R24	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼ 150kΩF		
R25, R26	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R27	A9101RG	Res: fxd met flm	150kΩ	±1%	¼W	LF¼ 150kΩF		
R28~R30								not assigned
R31	A9051RG	Res: fxd met flm	1.2kΩ	±1%	¼W	LF¼ 1.2kΩF		
R32	A9073RG	Res: fxd met flm	10kΩ	±1%	¼W	LF¼ 10kΩF		
R33	A9037RG	Res: fxd met flm	330Ω	±1%	¼W	LF¼ 330ΩF		
R34	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R35	A9060RG	Res: fxd met flm	3kΩ	±1%	¼W	LF¼ 3kΩF		
R36	A9049RG	Res: fxd met flm	1kΩ	±1%	¼W	LF¼ 1kΩF		
R37, R38	A9037RG	Res: fxd met flm	330Ω	±1%	¼W	LF¼ 330ΩF		
R39	A9001RG	Res: fxd met flm	10Ω	±1%	¼W	LF¼ 10ΩF		
R40								not assigned
R41	A9055RG	Res: fxd met flm	1.8kΩ	±1%	¼W	LF¼ 1.8kΩF		
R42	A9075RG	Res: fxd met flm	12kΩ	±1%	¼W	LF¼ 12kΩF		
R43	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		
R44	A9055RG	Res: fxd met flm	1.8kΩ	±1%	¼W	LF¼ 1.8kΩF		
R45	A9075RG	Res: fxd met flm	12kΩ	±1%	¼W	LF¼ 12kΩF		
R46	A9077RG	Res: fxd met flm	15kΩ	±1%	¼W	LF¼ 15kΩF		
R47, R48	A9025RG	Res: fxd met flm	100Ω	±1%	¼W	LF¼ 100ΩF		
R49, R50	A9063RG	Res: fxd met flm	3.9kΩ	±1%	¼W	LF¼ 3.9kΩF		
R51, R52	A9206RK	Res: fxd met flm	0.33Ω	±5%	½W	ERX-12ANJ 0.33Ω		
C1	A9406CA	Cap: fxd Al elect	6800μF	±20%	35V	ECES1VU682M		
C2	A9250CY	Cap: fxd polye flm	0.01μF	±10%	50V	MFL5002-103K		
C3	A9244CY	Cap: fxd polye flm	1000pF	±10%	50V	MFL5002-102K		
C4	A9441CA	Cap: fxd Al elect	22μF	±20%	35V	ECEA1VU220		
C5, C6	A9250CY	Cap: fxd polye flm	0.01μF	±10%	50V	MFL5002-103K		

Figure 5-13b. Power Supply Board Ass'y (for Models 2533E42 and 2533E43): B9278JN Components Location Diagram.

5-13. Power Supply Board Ass'y (for Models 2533E42 and 2533E43): B9278JN. (continued)

Item	Part No.	Part Name and Description				Remarks
C7~C9 C10	A9425CA	Cap: fxd Al elect	2200μF	±20%	25V KME25VB2200	not assigned
C11	A9248CY	Cap: fxd polye flm	4700pF	±10%	50V MFL5002-472K	
C12, C13	A9245CY	Cap: fxd polye flm	1500pF	±10%	50V MFL5002-152K	
C14	A9449CA	Cap: fxd Al elect	2200μF	±20%	35V ECEA1VU222	
C15	A9445CA	Cap: fxd Al elect	220μF	±20%	35V ECEA1VU221	
C16	A9449CA	Cap: fxd Al elect	2200μF	±20%	35V ECEA1VU222	
C17	A9445CA	Cap: fxd Al elect	220μF	±20%	35V ECEA1VU221	
C18~C20						
C21, C22	A9445CA	Cap: fxd Al elect	220μF	±20%	35V ECEA1VU221	
C23, C24	A9449CA	Cap: fxd Al elect	2200μF	±20%	35V ECEA1VU222	
C25, C26	A9251CY	Cap: fxd polye flm	0.015μF	±10%	50V MFL5002-153K	not assigned
C27, C28	A9418CA	Cap: fxd Al elect	2200μF	±20%	16V KME16VB2200	
C29, C30	A9114CC	Cap: fxd cer	0.1μF		50V RPE132-305F104Z50	
L1	A9084EC	Inductor	100μH		5A SKC-103	
L2, L3	A9043ML	Inductor	10μH		1A AF-012	
L4, L5	A9013ML	Inductor	26μH		2A SN-8S-300	
D1	A9385HD	Diode: zener			S5S3M	
D2	A9115HL	Diode: module			4G4B41	
D3	A9092HL	Diode: module			1G4B41	
D4, D5	A9302HD	Diode: zener			RD6.8E-B	
D6, D7	A9150HL	Diode: array			MC-931	5A/30 V
D8, D9	A9302HD	Diode: zener			RD6.8E-B	
D10	A9392HD	Diode: zener			S1S3M	
D11	A9392HD	Diode: zener			S1S3M	
D12	A9092HL	Diode: module			1G4B41	
Q1	A9340HQ	XSTR: Si NPN			2SC1815-Y	
Q2	A9338HQ	XSTR: Si PNP			2SA1015-Y	
Q3	A9452HQ	XSTR: Si NPN			2SC2235-Y	
Q4	A9477HQ	XSTR: Si PNP			2SA965-Y	
Q5	A9287HQ	XSTR: Si NPN			2SD1268-P	
Q6	A9477HQ	XSTR: Si PNP			2SA965-Y	not assigned
Q7	A9452HQ	XSTR: Si NPN			2SC2235-Y	
Q8, Q9	A9334HQ	XSTR: Si PNP			2SB943-P	
Q10						
Q11	A9338HQ	XSTR: Si PNP			2SA1015-Y	
Q12	A9340HQ	XSTR: Si NPN			2SC1815-Y	
U1	A9085LA	IC: analog			μPC271C	
U2	A9115LA	IC: analog			HA17524P	
U3	A9219LA	IC: analog			LF412CN	
U4	A9082LA	IC: analog			μPC4558C	
U5	A9192LA	IC: analog			LA6393D	
U6	A9104LA	IC: +12 V voltage regulator			μPC7812H	
U7	A9105LA	IC: -12 V voltage regulator			μPC7912H	

5-13. Power Supply Board Ass'y (for Models 2533E42 and 2533E43): B9278JN. (continued)

Item	Part No.	Part Name and Description		Remarks
CN1	A9244KP	Conn	5045-03A	3P
CN2	A9447KP	Conn	5281-10A	10P
CN3	A9246KP	Conn	5045-02A	2P
CN4	A9244KP	Conn	5045-03A	3P
CN5	A9462KP	Conn	5281-08A	8P
CN6	A9460KP	Conn	5281-03A	3P
TP1~TP5	A9574KP	Test point	VTC-1-1	
	B9278UA	Plate	(1 pc)	
	B9278UB	Plate	(1 pc)	
	Y9304LS	Screw: M3 X 4	(10 pcs)	
	B9278KN	PWB	(1 pc)	

CONTENTS

SELF TEST	S-2
1. ADJUSTMENT MANUAL	S-3
2. DISPLAY, KEYBOARD, AND DIGITAL FUNCTION INSPECTIONS	S-4
3. POWER SOURCE ADJUSTMENT AND CHECK	S-7
4. A/D ASSEMBLY ADJUSTMENT	S-8
5. RMS ASSEMBLY ADJUSTMENT INSTRUCTIONS	S-9
6. AC INPUT ASSEMBLY ADJUSTMENT INSTRUCTIONS ..	S-11
7. POWER RANGE ADJUSTMENT	S-13
8. DC INPUT ASSEMBLY ADJUSTMENT PROCEDURES	S-15
9. CHECK FREQUENCY ASSEMBLY DIP SWITCH (OPTIONAL)	S-18
10. INTEGRATOR ASSEMBLY ADJUSTMENT METHOD (OPTIONAL)	S-19
11. GP-IB FUNCTION	S-20
12. RANGING PERFORMANCE CHECK	S-21
13. ANALOG OUTPUT CHECK	S-21
14. OPTIONAL FUNCTION CHECKS	S-22
15. VOLTAGE TESTS	S-22
16. AC CURRENT TEST	S-24
17. POWER MEASUREMENT TESTS	S-25
18. VARIATIONS AND KEYBOARD LOCATIONS	S-27

12. RANGING PERFORMANCE CHECK

12.1 Automatic Range Switching (Check Voltage Range Only)

When the V_{rms}/V_{mean} ratio, expressed as a percentage exceeds approximately 110, the measured range switches automatically to the next highest range.

When the V_{rms}/V_{mean} ratio, expressed as a percentage falls below approximately 30, the measuring range switches automatically to the next lowest range.

12.2 Peak Over

Check to confirm that the voltage peak indicator lamp lights when the input voltage peak value exceeds approximately 250 % of range.

Check to confirm that the current peak indicator lamp lights when the current peak value exceeds approximately 350 % of range.

13. ANALOG OUTPUT CHECK

(1) Prepare Analog Output Connector with leads for:

V , V , V

A , A , A

W , W , W

(2) Connect AC Voltage and Current Standards according to the number of measuring elements in your unit and apply 100 V, 5 A, $\cos\phi = 1$ to unit and fix ranges at 100 V, 5 A.

(3) Using DMM, verify analog outputs to be:

5 V DC $\pm 0.25\%$ (± 0.0125 V DC)

(4) This concludes test of Analog Output.

14. OPTIONAL FUNCTION CHECKS

(1) GP-IB Interface Function Check

Use a controller with GP-IB control functions to confirm that function setting and range selection by remote control can be carried out correctly for each function.

(2) Frequency Measurement

Measure the input voltage and frequency. The accuracy must be $\pm (0.1 \% + 1 \text{ digit})$.

(3) Integrator Function Check

Use a standard AC voltage/current to apply 100 V AC to the voltage input terminals and 1 A AC to the current input terminals. After setting the timer to six minutes, press the "Wh" pushbutton switch, then press the integrator pushbutton switch to start integration. Confirm that the value displayed after six minutes is 10 Wh.

Integration accuracy must be $\pm (\text{instrument accuracy} + 0.02 \% \text{ of measurement value} + 1 \text{ digit})$

15. VOLTAGE TESTS

(1) Range and Frequency Characteristic Tests

(a) Test set Vrms mode

Apply a standard AC voltage, at the four frequencies of 10 Hz, 60 Hz, 2 kHz and 30 kHz, as listed in the following table read the display to the voltage input terminals and on each voltage range. Input voltage and reading accuracy must be as listed in the following table.

Range		30 V	60 V	100 V	150 V	300 V	600 V
Input Voltage		30 V	60 V	100 V	150 V	300 V	600 V
Accuracy	2533E3□	10Hz: $\pm (0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.1\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 10Hz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					

(b) Test set Vmean mode

Using a standard AC voltage, apply 100 V AC at four frequencies of 10 Hz, 60 Hz, 2 kHz, and 30 kHz to the voltage input terminals and read the display for each frequency. Accuracy must be as listed in the following table:

Frequency		10 Hz	60 Hz	2 kHz	20 kHz
Input Voltage		100 V fixed Range 100 V			
Accuracy	2533E3□	10Hz: $\pm (0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.1\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$			
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 10Hz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$			

(2) Linearity Test

The 100 V range shall be selected, and using a standard AC voltage apply an AC voltage at 60 Hz as listed in the following table to the voltage input terminals and read the display. The test points and accuracy must be as listed in the following table:

Input Voltage		10 V	20 V	60 V	110 V
Accuracy	2533E3□	60 Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$			
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$			

16. AC CURRENT TEST

The following tests shall be carried out for each test point in the CURRENT mode selected by the function selector switch.

(1) Range and Frequency Characteristic Tests

Using AC current standard apply an AC current at frequencies of 10 Hz, 60 Hz, 2 kHz and 30 kHz to the current input terminals and read the display on each range. The input current and accuracy for each range must be as listed in the following table:

Range		0.5 A	1 A	2 A	5 A	10 A	20 A
Input Current		0.5 A	1 A	2 A	5 A	10 A	20 A
Accuracy	2533E3□	10Hz: $\pm (0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range} + 3 \text{ mA})$ 10Hz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					

(2) Linearity Test

The 1 A range shall be selected and, using AC current standard apply an AC (or DC) current at 60 Hz as listed in the following table to the current input terminals and read the display.

The test points and accuracy must be as listed in the following table:

Input Current		0.1 A	0.2 A	0.6 A	1 A
Accuracy	2533E3□	60 Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$			
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range} + 3 \text{ mA})$ 60 Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$			

17. POWER MEASUREMENT TESTS

The following tests shall be carried out for each point in the WATT and Σ modes.

(1) Range and Frequency Characteristic Tests

Using standard AC (or DC) power apply AC (or DC) voltage and currents at power factor 1 to the input terminals and read the displayed power.

Voltage and current range setting, input voltage and current, frequency and accuracy shall be as in the table below.

Frequency, Factor		Voltage Range and Input Voltage	Current Range and Power Input Current
(D.C) 10 Hz	50/60 Hz	100 V fixed	0.5 A
			2 A
			5 A
			10 A
			20 A
	2 kHz	30 V	1 A fixed
	30 kHz	60 V	
		100 V	
		150 V	
	cosϕ: 1	300 V	
		600 V	
Accuracy	2533E3□	10Hz : ± (0.3% of rdg + 0.4% of range) 60Hz : ± (0.1% of rdg + 0.1% of range) 2kHz : ± (0.2% of rdg + 0.2% of range) 30kHz : ± 3% of range	
	2533E4□	DC : ± (0.1% of rdg + 0.3% of range) 10Hz : ± (0.3% of rdg + 0.4% of range) 60Hz : ± (0.1% of rdg + 0.2% of range) 2kHz : ± (0.2% of rdg + 0.4% of range) 30kHz : ± 3% of range	

(2) Linearity Test

Using AC power standard, apply the input voltages and currents listed in the following tables to each input terminal and read the displayed power. The current range, voltage range and accuracy must be as follows:

Item	Input Current and Voltage
Current range (1 A)	1 A fixed
Voltage range (100 V)	10 V, 20 V, 60 V, 110 V

Item	Input Voltage and Input Current
Voltage range (100 V)	100 V fixed
Current range (1 A)	0.1 A, 0.2 A, 0.6 A, 1.1 A

Power factor: 1, Frequency: 60 Hz

Accuracy	2533E3□	$\pm (0.1 \% \text{ of rdg} + 0.1 \% \text{ of range})$
	2533E4□	$\pm (0.1 \% \text{ of rdg} + 0.2 \% \text{ of range})$

(3) Power Factor Influence Test

With each phase power and Σ power, AC voltage and current at power factor zero (for both LEAD and LAG) listed in the following table shall be applied to each input terminals and the displayed power read.

Voltage Range and Input Voltage	Current Range and Input Current	Frequency	Accuracy
30 V	1 A fixed	60 Hz	$\pm (0.39 \% \text{ of range})$
60 V			
100 V			
150 V			
300 V			
600 V			

18. VARIATIONS AND KEYBOARD LOCATIONS

(1) 1 Phase (Model 2533E31)

FREQ. (Option)	GP-1B or RS232C
CPU	B9278JJ
INTEG (Option)	
DISPLAY CONT.	B9278JH
AD For 1 ϕ	B9278JV
RMS	1 B9278JB
AC INPUT	B9278JA
DISPLAY For 1 phase B9278EA	

(2) 3 Phase 3 Wire (Model 2533E32)

FREQ. (Option)	GP-1B or RS232C
CPU	B9278JJ
INTEG (Option)	
DISPLAY CONT.	B9278JH
AD For 3 ϕ	B9278JD
SUM MPX	B9278JC
RMS	3 B9278JB
RMS	1 B9278JB
AC INPUT	3 B9278JA
AC INPUT	1 B9278JA
DISPLAY For 3 phase B9278EB	

(3) 3 Phase 4 Wire (Model 2533E33)

FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
(INTEG Option)	
DISPLAY CONT.	B9278JH
AD For 3 ϕ	B9278JD
SUM MPX	B9278JC
RMS	☐ 3 B9278JB
RMS	☐ 2 B9278JB
RMS	☐ 1 B9278JB
AC INPUT	☐ 3 B9278JA
AC INPUT	☐ 2 B9278JA
AC INPUT	☐ 1 B9278JA
DISPLAY For 3 phase B9278EB	

(4) 1 Phase (Model 2533E41)

SUPPLY B9278JN	POWER B9278CU
FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
(INTEG Option)	
DISPLAY CONT.	B9278JH
AD For 1 ϕ	B9278JV
RMS	☐ 1 B9278JB
DC INPUT MOD.	B9278PA
DISPLAY For 1 phase B9278EA	

(5) 3 Phase 3 Wire (Model 2533E42)

SUPPLY B9278JN	POWER B9278CU
FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
(INTEG Option)	
DISPLAY CONT.	B9278JH
AD For 3 ϕ	B9278JD
SUM MPX	B9278JC
RMS	☐ 3 B9278JB
RMS	☐ 1 B9278JB
DC INPUT MOD.	☐ 3 B9278PA
DC INPUT MOD.	☐ 1 B9278PA
DISPLAY For 3 phase B9278EB	

(6) 3 Phase 4 Wire (Model 2533E43)

	SUPPLY B9278JN	POWER B9278CU
	FREQ. (Option)	GP-IB or RS232C
	CPU	B9278JJ
	INTEG (Option)	
	DISPLAY CONT.	B9278JH
	AD For 3 ϕ	B9278JD
	SUM MPX	B9278JC
	RMS	☐ 3 B9278JB
	RMS	☐ 2 B9278JB
	RMS	☐ 1 B9278JB
	DC INPUT MOD. ☐ 3	B9278PA
	DC INPUT MOD. ☐ 2	B9278PA
	DC INPUT MOD. ☐ 1	B9278PA
	DISPLAY For 3 phase B9278EB	

12. RANGING PERFORMANCE CHECK

12.1 Automatic Range Switching (Check Voltage Range Only)

When the V_{rms}/V_{mean} ratio, expressed as a percentage exceeds approximately 110, the measured range switches automatically to the next highest range.

When the V_{rms}/V_{mean} ratio, expressed as a percentage falls below approximately 30, the measuring range switches automatically to the next lowest range.

12.2 Peak Over

Check to confirm that the voltage peak indicator lamp lights when the input voltage peak value exceeds approximately 250 % of range.

Check to confirm that the current peak indicator lamp lights when the current peak value exceeds approximately 350 % of range.

13. ANALOG OUTPUT CHECK

(1) Prepare Analog Output Connector with leads for:

V , V , V

A , A , A

W , W , W

(2) Connect AC Voltage and Current Standards according to the number of measuring elements in your unit and apply 100 V, 5 A, $\cos\phi = 1$ to unit and fix ranges at 100 V, 5 A.

(3) Using DMM, verify analog outputs to be:

5 V DC $\pm 0.25\%$ (± 0.0125 V DC)

(4) This concludes test of Analog Output.

14. OPTIONAL FUNCTION CHECKS

(1) GP-IB Interface Function Check

Use a controller with GP-IB control functions to confirm that function setting and range selection by remote control can be carried out correctly for each function.

(2) Frequency Measurement

Measure the input voltage and frequency. The accuracy must be $\pm (0.1 \% + 1 \text{ digit})$.

(3) Integrator Function Check

Use a standard AC voltage/current to apply 100 V AC to the voltage input terminals and 1 A AC to the current input terminals. After setting the timer to six minutes, press the "Wh" pushbutton switch, then press the integrator pushbutton switch to start integration. Confirm that the value displayed after six minutes is 10 Wh.

Integration accuracy must be $\pm (\text{instrument accuracy} + 0.02 \% \text{ of measurement value} + 1 \text{ digit})$

15. VOLTAGE TESTS

(1) Range and Frequency Characteristic Tests

(a) Test set Vrms mode

Apply a standard AC voltage, at the four frequencies of 10 Hz, 60 Hz, 2 kHz and 30 kHz, as listed in the following table read the display to the voltage input terminals and on each voltage range. Input voltage and reading accuracy must be as listed in the following table.

Range		30 V	60 V	100 V	150 V	300 V	600 V
Input Voltage		30 V	60 V	100 V	150 V	300 V	600 V
Accuracy	2533E3□	10Hz: $\pm (0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.1\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 10Hz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					

(b) Test set Vmean mode

Using a standard AC voltage, apply 100 V AC at four frequencies of 10 Hz, 60 Hz, 2 kHz, and 30 kHz to the voltage input terminals and read the display for each frequency. Accuracy must be as listed in the following table:

Frequency		10 Hz	60 Hz	2 kHz	20 kHz
Input Voltage		100 V fixed Range 100 V			
Accuracy	2533E3□	10Hz: $\pm (0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.1\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$			
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 10Hz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$			

(2) Linearity Test

The 100 V range shall be selected, and using a standard AC voltage apply an AC voltage at 60 Hz as listed in the following table to the voltage input terminals and read the display. The test points and accuracy must be as listed in the following table:

Input Voltage		10 V	20 V	60 V	110 V
Accuracy	2533E3□	60 Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$			
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$			

16. AC CURRENT TEST

The following tests shall be carried out for each test point in the CURRENT mode selected by the function selector switch.

(1) Range and Frequency Characteristic Tests

Using AC current standard apply an AC current at frequencies of 10 Hz, 60 Hz, 2 kHz and 30 kHz to the current input terminals and read the display on each range. The input current and accuracy for each range must be as listed in the following table:

Range		0.5 A	1 A	2 A	5 A	10 A	20 A
Input Current		0.5 A	1 A	2 A	5 A	10 A	20 A
Accuracy	2533E3□	10Hz: $\pm (0.3\% \text{ of rdg} + 0.3\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.2\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range} + 3 \text{ mA})$ 10Hz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 60Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$ 2kHz: $\pm (0.2\% \text{ of rdg} + 0.4\% \text{ of range})$ 30kHz: $\pm 2\% \text{ of range}$					

(2) Linearity Test

The 1 A range shall be selected and, using AC current standard apply an AC (or DC) current at 60 Hz as listed in the following table to the current input terminals and read the display.

The test points and accuracy must be as listed in the following table:

Input Current		0.1 A	0.2 A	0.6 A	1 A
Accuracy	2533E3□	60 Hz: $\pm (0.1\% \text{ of rdg} + 0.1\% \text{ of range})$			
	2533E4□	DC: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range} + 3 \text{ mA})$ 60 Hz: $\pm (0.1\% \text{ of rdg} + 0.2\% \text{ of range})$			

17. POWER MEASUREMENT TESTS

The following tests shall be carried out for each point in the WATT and Σ modes.

(1) Range and Frequency Characteristic Tests

Using standard AC (or DC) power apply AC (or DC) voltage and currents at power factor 1 to the input terminals and read the displayed power.

Voltage and current range setting, input voltage and current, frequency and accuracy shall be as in the table below.

Frequency, Factor		Voltage Range and Input Voltage	Current Range and Power Input Current
(D.C) 10 Hz	50/60 Hz	100 V fixed	0.5 A
			2 A
			5 A
			10 A
			20 A
	2 kHz	30 V	1 A fixed
	30 kHz	60 V	
		100 V	
		150 V	
	cosφ: 1	300 V	
		600 V	
Accuracy	2533E3□	10Hz : ± (0.3% of rdg + 0.4% of range) 60Hz : ± (0.1% of rdg + 0.1% of range) 2kHz : ± (0.2% of rdg + 0.2% of range) 30kHz : ± 3% of range	
	2533E4□	DC : ± (0.1% of rdg + 0.3% of range) 10Hz : ± (0.3% of rdg + 0.4% of range) 60Hz : ± (0.1% of rdg + 0.2% of range) 2kHz : ± (0.2% of rdg + 0.4% of range) 30kHz : ± 3% of range	

(2) Linearity Test

Using AC power standard, apply the input voltages and currents listed in the following tables to each input terminal and read the displayed power. The current range, voltage range and accuracy must be as follows:

Item	Input Current and Voltage
Current range (1 A)	1 A fixed
Voltage range (100 V)	10 V, 20 V, 60 V, 110 V

Item	Input Voltage and Input Current
Voltage range (100 V)	100 V fixed
Current range (1 A)	0.1 A, 0.2 A, 0.6 A, 1.1 A

Power factor: 1, Frequency: 60 Hz

Accuracy	2533E3□	$\pm (0.1 \% \text{ of rdg} + 0.1 \% \text{ of range})$
	2533E4□	$\pm (0.1 \% \text{ of rdg} + 0.2 \% \text{ of range})$

(3) Power Factor Influence Test

With each phase power and Σ power, AC voltage and current at power factor zero (for both LEAD and LAG) listed in the following table shall be applied to each input terminals and the displayed power read.

Voltage Range and Input Voltage	Current Range and Input Current	Frequency	Accuracy
30 V	1 A fixed	60 Hz	$\pm (0.39 \% \text{ of range})$
60 V			
100 V			
150 V			
300 V			
600 V			

18. VARIATIONS AND KEYBOARD LOCATIONS

(1) 1 Phase (Model 2533E31)

FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
INTEG (Option)	
DISPLAY CONT.	B9278JH
AD For 1 ϕ	B9278JV
RMS	1 B9278JB
AC INPUT	B9278JA
DISPLAY For 1 phase B9278EA	

(2) 3 Phase 3 Wire (Model 2533E32)

FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
INTEG (Option)	
DISPLAY CONT.	B9278JH
AD For 3 ϕ	B9278JD
SUM MPX	B9278JC
RMS	3 B9278JB
RMS	1 B9278JB
AC INPUT	3 B9278JA
AC INPUT	1 B9278JA
DISPLAY For 3 phase B9278EB	

(3) 3 Phase 4 Wire (Model 2533E33)

FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
(INTEG Option)	
DISPLAY CONT.	B9278JH
AD For 3 ϕ	B9278JD
SUM MPX	B9278JC
RMS	☐ 3 B9278JB
RMS	☐ 2 B9278JB
RMS	☐ 1 B9278JB
AC INPUT	☐ 3 B9278JA
AC INPUT	☐ 2 B9278JA
AC INPUT	☐ 1 B9278JA
DISPLAY For 3 phase B9278EB	

(4) 1 Phase (Model 2533E41)

SUPPLY B9278JN	POWER B9278CU
FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
(INTEG Option)	
DISPLAY CONT.	B9278JH
AD For 1 ϕ	B9278JV
RMS	☐ 1 B9278JB
DC INPUT MOD.	B9278PA
DISPLAY For 1 phase B9278EA	

(5) 3 Phase 3 Wire (Model 2533E42)

SUPPLY B9278JN	POWER B9278CU
FREQ. (Option)	GP-IB or RS232C
CPU	B9278JJ
(INTEG Option)	
DISPLAY CONT.	B9278JH
AD For 3 ϕ	B9278JD
SUM MPX	B9278JC
RMS	☐ 3 B9278JB
RMS	☐ 1 B9278JB
DC INPUT MOD.	☐ 3 B9278PA
DC INPUT MOD.	☐ 1 B9278PA
DISPLAY For 3 phase B9278EB	

(6) 3 Phase 4 Wire (Model 2533E43)


	SUPPLY B9278JN	POWER B9278CU
	FREQ. (Option)	GP-IB or RS232C
	CPU	B9278JJ
	INTEG (Option)	
	DISPLAY CONT.	B9278JH
	AD For 3 ϕ	B9278JD
	SUM MPX	B9278JC
	RMS	☐ 3 B9278JB
	RMS	☐ 2 B9278JB
	RMS	☐ 1 B9278JB
	DC INPUT MOD. ☐ 3	B9278PA
	DC INPUT MOD. ☐ 2	B9278PA
	DC INPUT MOD. ☐ 1	B9278PA
	DISPLAY For 3 phase B9278EB	

Customer Maintenance Parts List


Model 2533E
Digital Power Meter


Model 2533E

MODEL 2533E 31



MODEL 2533E 32
MODEL 2533E 33






Item	Part No.	Qty	Description
1	B9278YQ	1	Cover
2	B9278BJ	2	Bumper
3	B9278FF	1	Plate
4	B9278FE	1	Plate
5	—	1	Internal Mechanism
6	B9278YT	2	Cover
7	B9278YR	1	Cover
8	B9564BH	2	Block
9	B9564BJ	2	Block
10	B9564YB	1	Red
11	Y9406LU	8	B.H. Screw, M4x6

Item	Part No.	Model	Qty			Description
			2533E31	2533E32	2533E33	
1	B9278CE	1	1	1		Power Assembly #1
	B9278CF	1	1	1		Power Assembly #2 } (select)
2	B9278CH	1	1	1		Bracket Assembly
3	B9278FH	1	1	1		Battery Case Assembly
4	Y9205KB	2	2	2		B.H. Screw, M2.3x5
5	A9027EF	1	1	1		Connector
6	Y9360EB	2	2	2		F.H. Screw, M3x6
7	A9072KF	1	1	1		Fuse Holder
8	A9050KF	1	1	1		Fuse #1 (1A, timelag)
	A9049KF	1	1	1		Fuse #2 (0.5A, timelag) } (select)
9	A9073KF	1	1	1		Fuse Carrier
10	A9174ZH	1	1	1		Terminal
11	Y9401WL	1	1	1		Washer (with toothed lockwasher)
12	Y9401CB	1	1	1		Nut
13	A9067SM	1	1	1		Switch #1
	A9068SM	1	1	1		Switch #2 } (select)
14	Y9308TS	2	2	2		Tapping Screw, M3x8
15	B9278LA	1	1	1		Transformer #1
	B9278LB	1	1	1		Transformer #2 } (select)
16	Y9406LB	4	4	4		B.H. Screw, M4x6
17	A9200SP	1	1	1		Switch
18	Y9306LB	2	2	2		B.H. Screw, M3x6
19	A9074ZG	1	1	1		Knob
20	B9278ES	1	1	1		Bracket
21	Y9308LB	1	1	1		B.H. Screw, M3x6
22	B9278JM	1	1	1		Supply Assembly
23	Y9406LB	2	2	2		B.H. Screw, M4x6
24	Y9410XH	2	2	2		Stud
25	Y9406LB	5	5	5		B.H. Screw, M4x6
26	B9278YL	2	2	2		Handle Assembly
27	B9278YM	1	1	1		Frame Assembly
28	B9278YU	1	1	1		Pipe
29	B9564BV	1	1	1		Spring
30	B9564BX	2	2	2		Bracket
31	Y9508EU	4	4	4		F.H. Screw, M5x8
32	B9278YP	1	1	1		Bracket
33	Y9405LB	2	2	2		B.H. Screw, M4x5
34	Y9406LB	4	4	4		B.H. Screw, M4x6
35	B9278YC	1				Panel Assembly
	B9278YD	1	1	1		Panel Assembly
36	B9278JW	1				Display Board
	B9278JK	1	1	1		Display Board
37	B9278EK	13	13	13		Stud
38	Y9305LB	13	13	13		B.H. Screw, M3x5
39	Y9304EB	13	13	13		F.H. Screw, M3x4
40	B9278YG	1				Sheet
	B9278YH	1	1	1		Sheet
41	A9073ZG	1	1	1		Bezel
42	Y9406LB	4	4	4		B.H. Screw, M4x6

Note

*1 : For 100V AC . Series


*2 : For 200V AC . Series



Item	Part No.	Model	Qty			Description
			2533E31	2533E32	2533E33	
1	B9278JT	1	1	1		Mother Assembly
	B9278JL		1	1		Mother Assembly
2	A9176KP	3	3	3		Stud
3	B9278CM	1	1	1		Case Assembly
4	Y9306LB	9	9	9		B.H. Screw, M3x6
5	Y9301BB	1	1	1		Nut
6	Y9310XH	3	3	3		Stud
7	B9278JB	1	2	3		RMS Assembly
8	B9278JC		1	1		SUM, MPX, Assembly
9	B9278ZD	1				A/D Assembly
	B9278ZC		1	1		A/D Assembly
10	B9278JH	1	1	1		Display Control Assembly
11	B9278ZG	1	1	1		Integrator Assembly *1
12	B9278JJ	1	1	1		CPU Assembly
13	B9278NA	1	1	1		ROM Assembly (U14)
14	B9278JR	1	1	1		FRQ Assembly *2
15	B9278ZE	1	1	1		GP-IB Assembly *3
	B9278ZF	1	1	1		RS232C Assembly *4
16	B9278ZN	1	1	1		Plate (for digital power meter without GP-IB or RS232C board)
17	B9278BR	1	1	1		Plate (for digital power meter without Integrator board)
18	Y9308LB	6	6	6		B.H. Screw, M3x8
19	Y9301WL	5	5	5		Washer (with toothed lockwasher)
20	B9278ZK	1	1	1		Bracket
21	A9026KY	1	1	1		Nylatch
22	A9024KY	1	1	1		Nylatch
23	B9278MB	1	2	3		Cable Assembly (input board ↔ RMS board)
24	B9278MA	1	1	1		Cable Assembly } (display control board ↔
25	B9278MB	1	1	1		Cable Assembly } display board)

Note


- *1 : For Model 2533E □□ /INTEG
- *2 : For Model 2533E □□ /FRQ
- *3 : For Model 2533E □□ /GP-IB
- *4 : For Model 2533E □□ /RS232C



CMPL 2533E-01E


May 1993

Item	Part No.	Model	Qty			Description
			2533E31	2533E32	2533E33	
1	B9278DW	1	1	1		Plate
2	B9200BQ	1	1	1		Name Plate
3	B9278BG	1	1	1		Bracket
4	Y9408LB	2	2	2		B.H. Screw, M4x8
5	Y9401WL	1	1	1		Washer (with toothed lockwasher)
6	B9278ZS	2	1			Plate
7	B9278DF	2	1			Bracket
8	B9278DG	2	1			Bracket
9	Y9305LB	7	7	7		B.H. Screw, M3x5
10	Y9308LB	8	4			B.H. Screw, M3x8
11	B9278DA	1	2	3		Input MOD, Assembly
12	B9278LF	1	1	1		Transformer Assembly (for power)
13	B9278FG	1	1	1		Cover
14	B9278FD	1	1	1		Plate (for Insulator)
15	A9088KY	1	1	1		Edging
16	Y9301CB	2	2	2		Nut
17	Y9306LB	2	2	2		B.H. Screw, M3x6
18	B9278DJ	1	1	1		Cover
19	B9278DM	2	2	2		Plate
20	B9278LM	1	1	1		Transformer (for CT)
21	B9278DL	1	1	1		Plate
22	Y9401CB	1	1	1		Nut
23	Y9435LB	1	1	1		B.H. Screw, M4x35
24	Y9305LB	5	5	5		B.H. Screw, M3x5
25	A9717KP	1	1	1		Edge Saddle
26	B9278DK	1	1	1		Cover
27	B9278JA	1	1	1		AC Input Assembly
28	Y9305LB	8	8	8		B.H. Screw, M3x5
29	Y9308XH	4	4	4		Stud
30	A9007ZH	2	2	2		Terminal Assembly
31	Y9401CB	2	2	2		Nut
32	Y9401TP	2	2	2		Tip
33	A9033ZH	2	2	2		Terminal Assembly
34	A9902TM	2	2	2		Tip



Item	Part No.	Model	Qty			Description
			2533E 31	2533E 32	2533E 33	
1	A9481ZJ		1	1		Nameplate ①
2	A9482ZJ			1		Nameplate ②
3	A9483ZJ		1	1		Nameplate ③
4	B9278ZT		1			Nameplate
5	B9278ZU				1	Nameplate
6	A9341ZJ	1	1	1		Nameplate (data plate)
7	B9278ZW	1	1	1		Nameplate
8	B9278ZV	1	1	1		Nameplate } (200V AC. series)

Standard Accessories



Item	Part No.	Qty	Description	
1	A1003JD	1	Connector	
2	B9278ZY	2	Bracket (for rack mount)	
3	A9050KF	2	Fuse (100 V AC, series) (1 A, timelag)	} (select)
	A9049KF	2	Fuse (200 V AC, series) (0.5 A, timelag)	
4	A9005ED	2	Battery	
5	A1006WD	1	Power Cord (UL standard)	} (select)
	A1253JZ	1	Adapter (3 to 2 pin conversion adapter)	
6	A1006WD	1	Power Cord (UL standard)	
7	A1009WD	1	Power Cord (VDE standard)	
8	A1024WD	1	Power Cord (SAA standard)	
9	A1023WD	1	Power Cord (BS standard)	
10	—	1	Instruction Manual	

